



ADDENDUM NO. 1

Date: November 20, 2014  
SOUTHEAST WASTEWATER TREATMENT PLANT  
OXIDATION DITCH VFD INSTALLATION  
Bid No. 15-11

**SCOPE:** This Addendum No 1 is to cover comments received during the Pre Bid Meeting that occurred on November 18, 2014.

**THE FOLLOWING SHALL BE INCLUDED AS PART OF THE BID DOCUMENTS:**

1. The Work to be bid is to include all labor, materials, and equipment necessary to perform the specified Work. Equipment to be installed is to be provided by the Contractor.
2. Interface into the SCADA software will be performed outside of this Contract. As part of this Contract, Contractor is to modify existing PLC program to accomplish the control strategy outlined within the specification.
3. Contractor is to mount Cabinet for the controller adjacent to the existing power panel at the Oxidation Ditch. Existing structure may be utilized provided that existing panels are properly relocated. Cabinet may be mounted on a new structure of the same build quality as the existing structure.

**Please acknowledge receipt of this Addendum No. 1 by signing and returning one copy with the Proposal document.**

Please do not hesitate to contact me at 618-457-3231, or Sean Pickford in Public Works Engineering Administration at 618-457-3284, if you have any questions regarding this addendum.

---

Christi Green  
Purchasing/Risk Management Specialist

---

Signature of Bidder

RETURN WITH BID