

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0001	2516 W Murphysboro RD Last Flow Test: 05/10/2018	671 gpm	
0002	W Main ST Last Flow Test: 04/17/2018	628 gpm	
0003	404 W Main ST Last Flow Test: 04/17/2018	822 gpm	
0004	416 W Main ST Last Flow Test: 04/17/2018	919 gpm	
0005	120 N Poplar ST Last Flow Test: 04/17/2018	1034 gpm	Elbow
0006	328 E Oak ST Last Flow Test: 04/23/2018	1233 gpm	Elbow
0007	2422 Union Hill RD Last Flow Test: 04/13/2018	531 gpm	Elbow
0008	300 W Jackson ST Last Flow Test: 04/17/2018	336 gpm	
0009	104 S Lark LANE Last Flow Test: 05/08/2018	628 gpm	
0010	104 N Illinois AVE Last Flow Test: 04/17/2018	1138 gpm	Elbow
0011	301 N Illinois AVE Last Flow Test: 04/17/2018	1163 gpm	Elbow
0012	300 W Oak ST Last Flow Test: 04/17/2018	1087 gpm	
0013	318 W Oak ST Last Flow Test: 04/17/2018	1034 gpm	
0014	500 W Oak ST Last Flow Test: 04/18/2018	475 gpm	
0015	512 W Oak ST Last Flow Test: 04/18/2018	628 gpm	
0016	700 W Main ST Last Flow Test: 04/18/2018	856 gpm	
0017	300 N Springer ST Last Flow Test: 04/18/2018	628 gpm	
0018	601 W Pecan ST Last Flow Test: 04/17/2018	628 gpm	
0019	413 W Pecan ST Last Flow Test: 04/17/2018	671 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0020	405 W Pecan ST Last Flow Test: 04/17/2018 531 gpm		
0021	328 N University AVE Last Flow Test: 04/17/2018 628 gpm		
0022	401 N Illinois AVE Last Flow Test: 05/14/2018 978 gpm	Elbow	
0023	520 N University AVE Last Flow Test: 04/19/2018 237 gpm	Elbow	
0024	402 W Sycamore ST Last Flow Test: 04/19/2018 237 gpm		
0025	503 W Sycamore ST Last Flow Test: 04/19/2018 1113 gpm	Elbow	
0026	410 N Springer ST Last Flow Test: 04/17/2018 1007 gpm		
0027	801 W Sycamore ST Last Flow Test: 04/23/2018 1061 gpm		
0028	900 W Sycamore ST Last Flow Test: 04/23/2018 1061 gpm		
0029	807 W Pecan ST Last Flow Test: 04/17/2018 712 gpm		
0030	701 W Pecan ST Last Flow Test: 04/17/2018 581 gpm	Elbow	
0031	807 W High ST Last Flow Test: 04/18/2018 237 gpm		
0032	104 N Oakland AVE Last Flow Test: 04/18/2018 888 gpm		
0033	1301 W Main ST Last Flow Test: 04/20/2018 1034 gpm		
0034	1412 W Main ST Last Flow Test: 04/20/2018 1007 gpm		
0035	1400 W Main ST Last Flow Test: 04/20/2018 168 gpm		
0036	1702A W Main ST Last Flow Test: 05/15/2018 1061 gpm		
0037	1702C W Main ST Last Flow Test: 04/24/2018 1138 gpm	Elbow (2)	
0038	300 N Smith ST Last Flow Test: 04/23/2018 628 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0039	1012 W Linden ST Last Flow Test: 04/23/2018 628 gpm	Elbow	
0040	104 W Bleyer ST Last Flow Test: 04/23/2018 581 gpm	Elbow	
0041	1100 W Main ST Last Flow Test: 04/20/2018 1007 gpm	Elbow	
0042	110 N Williams ST Last Flow Test: 04/23/2018 531 gpm	Elbow	
0043	1921 W Sycamore ST Last Flow Test: 05/14/2018 0 gpm		
0044	1705 W Sycamore ST Last Flow Test: 04/24/2018 1061 gpm		
0045	1500 W Sycamore ST Last Flow Test: 04/24/2018 1138 gpm		
0046	1300 W Sycamore ST Last Flow Test: 04/24/2018 1113 gpm	Elbow	
0047	1117 W Sycamore ST Last Flow Test: 04/24/2018 671 gpm	Elbow	
0048	1009 W Sycamore ST Last Flow Test: 04/24/2018 531 gpm		
0049	919 W Sycamore ST Last Flow Test: 04/20/2018 628 gpm		
0050	914 W Pecan ST Last Flow Test: 04/23/2018 581 gpm	Elbow	
0051	900 W Pecan ST Last Flow Test: 04/23/2018 531 gpm	Elbow	
0052	906 W Pecan ST Last Flow Test: 04/23/2018 581 gpm	Elbow	
0053	415 N Illinois AVE Last Flow Test: 05/14/2018 1061 gpm	Elbow	
0054	201 W Chestnut ST Last Flow Test: 04/19/2018 1113 gpm	Elbow	
0055	521 N Davis ST Last Flow Test: 04/19/2018 822 gpm	Elbow	
0056	503 N Davis ST Last Flow Test: 04/19/2018 671 gpm	Elbow	
0057	313 W Chestnut ST Last Flow Test: 04/19/2018 1210 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0058	526 N Michaels ST Last Flow Test: 04/19/2018 1138 gpm	Elbow	
0059	700 N Carico ST Last Flow Test: 04/19/2018 1163 gpm	Elbow	
0060	601 N Carico ST Last Flow Test: 04/19/2018 628 gpm	Elbow	
0061	426 W Hickory ST Last Flow Test: 04/19/2018 1087 gpm	Elbow	
0062	408 W Chestnut ST Last Flow Test: 04/19/2018 1113 gpm	Elbow	
0063	521 N Almond ST Last Flow Test: 04/19/2018 1113 gpm	Elbow	
0064	513 N Springer ST Last Flow Test: 04/23/2018 919 gpm		
0065	521 N Springer ST Last Flow Test: 04/23/2018 1061 gpm		
0066	525 Allyn ST Last Flow Test: 04/23/2018 949 gpm		
0067	513 Allyn ST Last Flow Test: 04/23/2018 750 gpm		
0068	511 N Oakland AVE Last Flow Test: 04/23/2018 712 gpm		
0069	519 N Oakland AVE Last Flow Test: 04/23/2018 1061 gpm		
0070	615 N Oakland AVE Last Flow Test: 04/23/2018 1061 gpm	Elbow	
0071	619 Allyn ST Last Flow Test: 04/23/2018 1007 gpm		
0072	605 N Springer ST Last Flow Test: 04/23/2018 1007 gpm		
0073	621 N Springer ST Last Flow Test: 04/23/2018 1034 gpm	Elbow	
0074	700 N Almond ST Last Flow Test: 04/24/2018 919 gpm	Elbow	
0075	709 N Bridge ST Last Flow Test: 04/23/2018 1087 gpm		
0076	410 W Willow ST Last Flow Test: 05/09/2018 750 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0077	400 W Willow ST Last Flow Test: 04/24/2018 949 gpm	Elbow	
0078	1695 McLafferty RD Last Flow Test: 05/11/2018 888 gpm	Elbow	
0079	211 W Willow ST Last Flow Test: 04/24/2018 1061 gpm	Elbow	
0080	610 N Illinois AVE Last Flow Test: 05/14/2018 1061 gpm		
0081	2151 W Ramada LN Last Flow Test: 04/25/2018 531 gpm	Elbow	
0082	710 N Illinois AVE Last Flow Test: 05/14/2018 1061 gpm	Elbow	
0083	1000 N Michaels ST Last Flow Test: 04/25/2018 1163 gpm	Elbow	
0084	1040 N Michaels ST Last Flow Test: 04/25/2018 1138 gpm	Elbow	
0085	1104 N Carico ST Last Flow Test: 04/25/2018 1138 gpm	Elbow	
0086	414 W Sycamore ST Last Flow Test: 04/19/2018 949 gpm	Elbow	
0087	1026 N Carico ST Last Flow Test: 04/24/2018 1061 gpm	Elbow	
0088	713 N Carico ST Last Flow Test: 04/23/2018 1113 gpm	Elbow	
0089	808 N Carico ST Last Flow Test: 04/24/2018 1034 gpm	Elbow	
0090	N Bridge ST Last Flow Test: 04/24/2018 1061 gpm	Elbow	
0091	500 N Kennicott ST Last Flow Test: 04/24/2018 1061 gpm	Elbow	
0092	500 Baird ST Last Flow Test: 04/24/2018 1138 gpm	Elbow	
0093	1026 N Bridge ST Last Flow Test: 04/24/2018 1007 gpm	Elbow	
0094	1200 N Bridge ST Last Flow Test: 04/25/2018 1210 gpm	Elbow	
0095	1213 N Bridge ST Last Flow Test: 04/25/2018 1210 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0096	511 Owens ST Last Flow Test: 04/25/2018 1034 gpm	Elbow	
0097	601 Owens ST Last Flow Test: 04/25/2018 787 gpm	Elbow	
0098	621 Owens ST Last Flow Test: 04/26/2018 856 gpm		
0099	601 W Rigdon ST Last Flow Test: 04/25/2018 1138 gpm	Elbow	
0100	512 Baird ST Last Flow Test: 04/24/2018 919 gpm	Elbow	
0101	815 N Almond ST Last Flow Test: 04/24/2018 919 gpm	Elbow	
0102	800 N Springer ST Last Flow Test: 04/24/2018 949 gpm	Elbow	
0103	812 N Springer ST Last Flow Test: 04/24/2018 949 gpm	Elbow	
0104	823 Allyn ST Last Flow Test: 04/24/2018 750 gpm	Elbow	
0105	803 Allyn ST Last Flow Test: 04/24/2018 712 gpm	Elbow	
0106	800 N James ST Last Flow Test: 04/24/2018 750 gpm	Elbow	
0107	810 N James ST Last Flow Test: 04/24/2018 750 gpm	Elbow	
0108	613 W Rigdon ST Last Flow Test: 04/25/2018 1061 gpm	Elbow	
0109	629 W Rigdon ST Last Flow Test: 04/25/2018 1113 gpm	Elbow	
0110	1017 N Oakland AVE Last Flow Test: 05/14/2018 1163 gpm	Elbow	
0111	714 N Oakland AVE Last Flow Test: 05/14/2018 1113 gpm	Elbow	
0112	1007 Laurel ST Last Flow Test: 04/20/2018 750 gpm		
0113	1015 Laurel ST Last Flow Test: 04/20/2018 822 gpm	Elbow	
0114	1005 N Hunter Woods AVE Last Flow Test: 04/20/2018 750 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0115	1021 Laurel ST Last Flow Test: 04/20/2018 712 gpm	Elbow	
0116	1026 W Willow ST Last Flow Test: 04/20/2018 856 gpm	Elbow	
0117	1020 W Willow ST Last Flow Test: 04/20/2018 822 gpm	Elbow	
0118	1012 W Willow ST Last Flow Test: 04/20/2018 787 gpm	Elbow	
0119	1108 W Willow ST Last Flow Test: 04/20/2018 856 gpm		
0120	700 Billy Bryan ST Last Flow Test: 04/20/2018 919 gpm		
0121	1100 W Jefferson ST Last Flow Test: 04/20/2018 1163 gpm		
0122	1104 W Jefferson ST Last Flow Test: 04/20/2018 856 gpm	Elbow	
0123	1207 W Jefferson ST Last Flow Test: 04/20/2018 671 gpm	Elbow	
0124	701 McKinley ST Last Flow Test: 04/20/2018 712 gpm		
0125	715 N McKinley ST Last Flow Test: 04/24/2018 475 gpm	Elbow	
0126	1220 W Short DR Last Flow Test: 04/24/2018 411 gpm		
0127	1228 W Short DR Last Flow Test: 04/24/2018 411 gpm		
0128	801 N McKinley ST Last Flow Test: 04/24/2018 411 gpm		
0129	1204 N McKinley ST Last Flow Test: 04/24/2018 411 gpm	Elbow	
0130	2939 W Murphysboro RD Last Flow Test: 05/11/2018 336 gpm		
0131	1200 N Oakland AVE Last Flow Test: 04/26/2018 949 gpm		
0132	1331 N Oakland AVE Last Flow Test: 04/26/2018 1087 gpm		
0133	500 W Cement Plant Last Flow Test: 04/26/2018 1061 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0134	111 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	237 gpm	
0135	297 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	475 gpm	
0136	449 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	531 gpm	
0137	55 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	237 gpm	
0138	96 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	671 gpm	
0139	357 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	531 gpm	
0140	408 Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	0 gpm	
0141	Carbondale Mobile Home Tr Last Flow Test: 04/26/2018	475 gpm	
0142	1215 E Walnut ST Last Flow Test: 05/15/2018	919 gpm	Elbow
0143	1550 N Oakland AVE Last Flow Test: 04/26/2018	1034 gpm	
0144	N Oakland AVE Last Flow Test: 04/26/2018	1087 gpm	
0145	801 Industrial Park RD Last Flow Test: 04/26/2018	1061 gpm	Elbow
0146	800A Industrial Park RD Last Flow Test: 04/26/2018	1061 gpm	
0147	800C Industrial Park RD Last Flow Test: 05/14/2018	1087 gpm	
0148	701 Industrial Park RD Last Flow Test: 04/26/2018	1061 gpm	
0149	420A Industrial Park RD Last Flow Test: 04/26/2018	1061 gpm	
0150	420C Industrial Park RD Last Flow Test: 05/14/2018	1087 gpm	Elbow
0151	501 Industrial Park RD Last Flow Test: 04/26/2018	1113 gpm	
0152	210 Industrial Park RD Last Flow Test: 04/26/2018	1061 gpm	Elbow

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0153	215 Industrial Park RD Last Flow Test: 04/26/2018 1138 gpm	Elbow	
0154	509 Helen ST Last Flow Test: 04/20/2018 1034 gpm		
0155	910 W McDaniel ST Last Flow Test: 04/20/2018 919 gpm		
0156	1900 N Illinois AVE Last Flow Test: 04/27/2018 1113 gpm		
0157	2250 N Illinois AVE Last Flow Test: 04/30/2018 856 gpm		
0158	2370 N Illinois AVE Last Flow Test: 04/30/2018 949 gpm		
0159	300 E Dillinger RD Last Flow Test: 04/27/2018 1113 gpm		
0160	350 Dillinger RD Last Flow Test: 04/27/2018 1034 gpm	Elbow	
0161	450 Dillinger RD Last Flow Test: 04/27/2018 888 gpm	Elbow	
0162	2370 N McRoy DR Last Flow Test: 04/30/2018 1163 gpm		
0163	2371 McRoy DR Last Flow Test: 04/30/2018 1113 gpm		
0164	2350 N McRoy DR Last Flow Test: 04/30/2018 1087 gpm		
0165	2320 N McRoy DR Last Flow Test: 04/30/2018 0 gpm		
0166	2301 N McRoy DR Last Flow Test: 04/30/2018 1007 gpm		
0167	2200 McRoy DR Last Flow Test: 04/27/2018 949 gpm		
0168	2170 McRoy DR Last Flow Test: 04/27/2018 919 gpm		
0169	2150 N McRoy DR Last Flow Test: 04/27/2018 1113 gpm		
0170	2100 McRoy DR Last Flow Test: 04/27/2018 978 gpm	Elbow	
0171	2050 N McRoy DR Last Flow Test: 04/27/2018 822 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0172	955 Villa CT Last Flow Test: 04/27/2018 822 gpm	Elbow	
0173	1419 Dogwood RD Last Flow Test: 05/02/2018 1007 gpm	Elbow	
0174	1045 New Era RD Last Flow Test: 04/25/2018 787 gpm		
0175	2300 W Main ST Last Flow Test: 04/25/2018 822 gpm	Elbow	
0176	2400A W Main ST Last Flow Test: 04/25/2018 787 gpm		
0177	2400B W Main ST Last Flow Test: 04/25/2018 856 gpm	Elbow	
0178	2400C W Main ST Last Flow Test: 04/25/2018 888 gpm	Elbow	
0179	2201 W Ramada LN Last Flow Test: 04/25/2018 750 gpm	Elbow	
0180	919 Norwest LN Last Flow Test: 04/27/2018 712 gpm		
0181	2400 Norwest LN Last Flow Test: 04/27/2018 712 gpm		
0182	2609 Striegel RD Last Flow Test: 04/27/2018 712 gpm		
0183	101 N Washington ST Last Flow Test: 04/20/2018 888 gpm	Elbow	
0184	106 E Jackson ST Last Flow Test: 04/20/2018 1087 gpm	Elbow	
0185	221 N Washington ST Last Flow Test: 04/20/2018 1163 gpm	Elbow	
0186	200 E James and Thelma Walker AVE Last Flow Test: 04/23/2018 1186 gpm	Elbow	
0187	415 N Washington ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0188	201 E Chestnut ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0189	701 N Washington ST Last Flow Test: 04/24/2018 1233 gpm	Elbow	
0190	801 N Washington ST Last Flow Test: 04/25/2018 1210 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0191	200 E Sycamore ST Last Flow Test: 04/25/2018 1113 gpm		
0192	918 N Washington ST Last Flow Test: 04/25/2018 1087 gpm		
0193	1200 N Marion ST Last Flow Test: 04/30/2018 411 gpm		
0194	925 N Marion ST Last Flow Test: 04/25/2018 1113 gpm	Elbow	
0195	913 N Marion ST Last Flow Test: 04/25/2018 1233 gpm	Elbow	
0196	901 N Marion ST Last Flow Test: 04/25/2018 1186 gpm	Elbow	
0197	910 N Bolden AVE Last Flow Test: 04/25/2018 750 gpm		
0198	812 N Marion ST Last Flow Test: 04/25/2018 1163 gpm		
0199	300 E Willow ST Last Flow Test: 04/25/2018 1256 gpm		
0200	300 E Birch ST Last Flow Test: 04/24/2018 1256 gpm	Elbow	
0201	506 N Marion ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0202	211 E Chestnut ST Last Flow Test: 04/24/2018 1163 gpm	Elbow	
0203	401 N Marion ST Last Flow Test: 04/23/2018 1233 gpm	Elbow	
0204	300 E Oak ST Last Flow Test: 04/20/2018 1034 gpm	Elbow	
0205	218 E Jackson ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0206	222 E Main ST Last Flow Test: 04/20/2018 1256 gpm	Elbow	
0207	1432 N Wall ST Last Flow Test: 04/26/2018 1061 gpm	Elbow	
0208	647 E Knight ST Last Flow Test: 04/27/2018 1007 gpm	Elbow	
0209	600 E Knight ST Last Flow Test: 04/26/2018 1186 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0210	520 E Knight ST Last Flow Test: 04/26/2018 1186 gpm	Elbow	
0211	1409 N Robert A. Stalls AVE Last Flow Test: 04/26/2018 1186 gpm	Elbow	
0212	1123 Allman ST Last Flow Test: 04/26/2018 1186 gpm		
0213	1221 N Robert A. Stalls AVE Last Flow Test: 04/26/2018 1210 gpm	Elbow	
0214	1207 N Pierce ST Last Flow Test: 04/26/2018 1138 gpm	Elbow	
0215	1415 N Wall ST Last Flow Test: 04/26/2018 1163 gpm	Elbow	
0216	647 E Jenkins ST Last Flow Test: 04/27/2018 978 gpm	Elbow	
0217	613 E Burke ST Last Flow Test: 04/27/2018 978 gpm	Elbow	
0218	713 E Searing ST Last Flow Test: 04/26/2018 671 gpm	Elbow	
0219	647 Searing ST Last Flow Test: 04/26/2018 1034 gpm	Elbow	
0220	1201 N Wall ST Last Flow Test: 04/26/2018 1256 gpm		
0221	521 E Fisher ST Last Flow Test: 04/26/2018 1186 gpm	Elbow	
0222	508 E Fisher ST Last Flow Test: 04/26/2018 628 gpm	Elbow	
0223	1100 N Robert A. Stalls AVE Last Flow Test: 04/26/2018 1163 gpm		
0224	1101 Allman ST Last Flow Test: 04/26/2018 1210 gpm		
0225	408 E Fisher ST Last Flow Test: 04/25/2018 1233 gpm	Elbow	
0226	400 E Larch ST Last Flow Test: 04/25/2018 1113 gpm	Elbow	
0227	412 E Larch ST Last Flow Test: 04/25/2018 1186 gpm	Elbow	
0228	500 E Larch ST Last Flow Test: 04/25/2018 1210 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0229	506 E Larch ST Last Flow Test: 04/25/2018 1113 gpm		
0230	516 E Russell ST Last Flow Test: 04/25/2018 1163 gpm	Elbow	
0231	500 E Russell ST Last Flow Test: 04/25/2018 1256 gpm	Elbow	
0232	518 E Larch ST Last Flow Test: 04/25/2018 1300 gpm		
0233	502 N Wall ST Last Flow Test: 04/24/2018 1233 gpm	Elbow	
0234	810 N Wall ST Last Flow Test: 04/25/2018 1138 gpm		
0235	524 E Sycamore ST Last Flow Test: 04/25/2018 1087 gpm	Elbow	
0236	813 N Robert A. Stalls AVE Last Flow Test: 04/25/2018 1087 gpm		
0237	416 E Sycamore ST Last Flow Test: 04/25/2018 1034 gpm	Elbow	
0238	400 E Sycamore ST Last Flow Test: 04/25/2018 1087 gpm	Elbow	
0239	304 E Sycamore ST Last Flow Test: 04/25/2018 1186 gpm	Elbow	
0240	400 E Willow ST Last Flow Test: 04/25/2018 1113 gpm	Elbow	
0241	416 E Willow ST Last Flow Test: 04/25/2018 1233 gpm	Elbow	
0242	500 E Willow ST Last Flow Test: 04/25/2018 1256 gpm	Elbow	
0243	512 E Willow ST Last Flow Test: 04/25/2018 1256 gpm	Elbow	
0244	800 N Wall ST Last Flow Test: 04/25/2018 1186 gpm		
0245	1008 N Wall ST Last Flow Test: 04/25/2018 1113 gpm		
0246	1004 N Wall ST Last Flow Test: 05/16/2018 1138 gpm	Elbow	
0247	700 N Wall ST Last Flow Test: 04/24/2018 1278 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0248	1213 N Wall ST Last Flow Test: 04/26/2018 1233 gpm	Elbow	
0249	514 E Birch ST Last Flow Test: 04/24/2018 1113 gpm	Elbow	
0250	701 N Robert A. Stalls AVE Last Flow Test: 04/24/2018 1138 gpm	Elbow	
0251	318 E Birch ST Last Flow Test: 04/24/2018 1007 gpm	Elbow	
0252	401 E Chestnut ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0253	413 E Chestnut ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0254	500 E Chestnut ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0255	512 E Chestnut ST Last Flow Test: 04/24/2018 1186 gpm	Elbow	
0256	518 E Chestnut ST Last Flow Test: 04/24/2018 1300 gpm	Elbow	
0257	531 Archie Jones Last Flow Test: 04/23/2018 1138 gpm	Elbow	
0258	511 Archie Jones Last Flow Test: 04/23/2018 1061 gpm	Elbow	
0259	400 N Wall ST Last Flow Test: 04/23/2018 919 gpm	Elbow	
0260	525 E James and Thelma Walker AVE Last Flow Test: 04/23/2018 1186 gpm	Elbow	
0261	501 E James and Thelma Walker AVE Last Flow Test: 04/23/2018 1233 gpm	Elbow	
0262	411 N Robert A. Stalls AVE Last Flow Test: 04/24/2018 1210 gpm	Elbow	
0263	311 E James and Thelma Walker AVE Last Flow Test: 04/23/2018 1233 gpm	Elbow	
0264	322 E Oak ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0265	408 E Oak ST Last Flow Test: 04/23/2018 1210 gpm	Elbow	
0266	421 E Oak ST Last Flow Test: 04/23/2018 1256 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0267	429 E Oak ST Last Flow Test: 04/23/2018 1300 gpm	Elbow	
0268	701 E Oak ST Last Flow Test: 04/17/2018 822 gpm		
0269	955 Villa CT Last Flow Test: 04/30/2018 671 gpm		
0270	430 E Jackson ST Last Flow Test: 04/20/2018 1256 gpm	Elbow	
0271	404 E Jackson ST Last Flow Test: 04/20/2018 168 gpm		
0272	314 E Jackson ST Last Flow Test: 04/20/2018 168 gpm		
0273	1250A E Main ST Last Flow Test: 05/09/2018 1138 gpm	Elbow	
0274	1310A E Main ST Last Flow Test: 05/09/2018 1007 gpm	Elbow	
0275	1270 E Main ST Last Flow Test: 05/08/2018 1186 gpm	Elbow	
0276	1250C E Main ST Last Flow Test: 05/08/2018 1256 gpm	Elbow	
0277	1250B E Main ST Last Flow Test: 05/09/2018 1186 gpm	Elbow	
0278	2400 Reed Station PKY Last Flow Test: 04/30/2018 1233 gpm		
0279	1230 E Main ST Last Flow Test: 05/09/2018 1210 gpm	Elbow	
0280	1181 E Main ST Last Flow Test: 05/08/2018 1300 gpm	Elbow	
0281	1160 E Main ST Last Flow Test: 05/10/2018 822 gpm		
0282	1170D E Main ST Last Flow Test: 05/08/2018 1278 gpm	Elbow	
0283	1170C E Main ST Last Flow Test: 05/08/2018 1278 gpm	Elbow	
0284	1170B E Main ST Last Flow Test: 05/08/2018 1300 gpm		
0285	1150C E Main ST Last Flow Test: 05/08/2018 1300 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0286	1150B E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0287	1170A E Main ST Last Flow Test: 05/10/2018 1113 gpm		
0288	1150A E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0289	1120 E Main ST Last Flow Test: 05/08/2018 1321 gpm	Elbow	
0290	1040 E Main ST Last Flow Test: 04/17/2018 1233 gpm	Elbow	
0291	1039 E Main ST Last Flow Test: 04/17/2018 1233 gpm	Elbow	
0292	1241 E Walnut ST Last Flow Test: 05/15/2018 919 gpm	Elbow	
0293	1000 E Main ST Last Flow Test: 04/17/2018 978 gpm	Elbow	
0294	816 E Main ST Last Flow Test: 04/17/2018 168 gpm		
0295	801 E Main ST Last Flow Test: 04/17/2018 168 gpm	Elbow	
0296	800 E Main ST Last Flow Test: 04/17/2018 168 gpm		
0297	800D E Main ST Last Flow Test: 04/17/2018 1087 gpm		
0298	701 E Main ST Last Flow Test: 04/17/2018 168 gpm		
0299	610 E Main ST Last Flow Test: 04/17/2018 168 gpm		
0300	955 Villa CT Last Flow Test: 04/30/2018 712 gpm	Elbow	
0301	410 E Main ST Last Flow Test: 04/20/2018 1061 gpm	Elbow	
0302	317 E Main ST Last Flow Test: 04/20/2018 1007 gpm	Elbow	
0303	223 E Main ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0304	201 S Washington ST Last Flow Test: 04/20/2018 1233 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0305	609 W Walnut ST Last Flow Test: 04/11/2018 919 gpm	Elbow	
0306	211 S Washington ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0307	301 S Marion ST Last Flow Test: 04/20/2018 1256 gpm	Elbow	
0308	315 E Walnut ST Last Flow Test: 04/20/2018 1278 gpm	Elbow	
0309	501 E Walnut ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0310	955 Villa CT Last Flow Test: 04/30/2018 787 gpm		
0311	2220 N Illinois AVE Last Flow Test: 04/30/2018 978 gpm	Elbow	
0312	500 E Snider ST Last Flow Test: 04/19/2018 1034 gpm		
0313	414 S Logan AVE Last Flow Test: 04/19/2018 531 gpm		
0314	311 E Elm ST Last Flow Test: 04/19/2018 475 gpm		
0315	400 S Marion ST Last Flow Test: 04/19/2018 1138 gpm		
0316	307 S Washington ST Last Flow Test: 04/19/2018 237 gpm	Elbow	
0317	415 S Washington ST Last Flow Test: 04/19/2018 237 gpm	Elbow	
0318	510 E College ST Last Flow Test: 04/19/2018 1087 gpm		
0319	500 E College ST Last Flow Test: 04/19/2018 1210 gpm		
0320	316 E College ST Last Flow Test: 04/19/2018 1210 gpm		
0321	212 E College ST Last Flow Test: 04/19/2018 1061 gpm		
0322	501 S Washington ST Last Flow Test: 05/16/2018 888 gpm		
0323	605 S Washington ST Last Flow Test: 04/19/2018 919 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0324	215 E Freeman ST Last Flow Test: 04/19/2018 1007 gpm		
0325	307 E Freeman ST Last Flow Test: 04/19/2018 1138 gpm		
0326	605 S Logan AVE Last Flow Test: 04/19/2018 1061 gpm		
0327	319 E Mill ST Last Flow Test: 04/19/2018 1138 gpm	Elbow	
0328	511 S Graham AVE Last Flow Test: 04/19/2018 1034 gpm		
0329	409 E Mill ST Last Flow Test: 04/19/2018 1163 gpm	Elbow	
0330	1400 Bradford LN Last Flow Test: 05/02/2018 856 gpm	Elbow	
0331	900 S Elizabeth ST Last Flow Test: 05/14/2018 978 gpm	Elbow	
0332	322 E Hester ST Last Flow Test: 04/18/2018 1163 gpm	Elbow	
0333	300 E Hester ST Last Flow Test: 04/18/2018 1138 gpm		
0334	701 S Washington ST Last Flow Test: 04/19/2018 0 gpm		
0335	300 E Stoker ST Last Flow Test: 04/18/2018 1007 gpm		
0336	312 E Stoker ST Last Flow Test: 04/18/2018 750 gpm	Diffuser	
0337	501 E Stoker ST Last Flow Test: 04/18/2018 628 gpm		
0338	625 N Giant City RD Last Flow Test: 05/14/2018 1186 gpm	Elbow	
0339	625 N Giant City RD Last Flow Test: 05/14/2018 1210 gpm	Elbow	
0340	625 N Giant City RD Last Flow Test: 05/14/2018 1163 gpm	Elbow	
0341	401 E Grand AVE Last Flow Test: 04/18/2018 1186 gpm		
0342	301 E Grand AVE Last Flow Test: 04/18/2018 1138 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0343	625 N Giant City RD Last Flow Test: 05/15/2018 1163 gpm	Elbow	
0344	615 S Washington ST Last Flow Test: 04/19/2018 856 gpm		
0345	603 E College ST Last Flow Test: 04/13/2018 949 gpm		
0346	602 E College ST Last Flow Test: 04/13/2018 822 gpm		
0347	615 E College ST Last Flow Test: 04/13/2018 949 gpm		
0348	707 E College ST Last Flow Test: 04/13/2018 1034 gpm		
0349	830 E College ST Last Flow Test: 04/13/2018 712 gpm		
0350	Bradford LN Last Flow Test: 05/02/2018 712 gpm		
0351	Bradford LN Last Flow Test: 05/02/2018 671 gpm		
0352	Bradford LN Last Flow Test: 05/01/2018 581 gpm		
0353	612 E Walnut ST Last Flow Test: 04/17/2018 1186 gpm	Elbow	
0354	634 E Walnut ST Last Flow Test: 04/17/2018 531 gpm	Elbow	
0355	302 S Walker ST Last Flow Test: 04/13/2018 531 gpm		
0356	606 E Snider ST Last Flow Test: 04/13/2018 888 gpm	Elbow	
0357	402 S Walker ST Last Flow Test: 04/13/2018 1113 gpm	Elbow	
0358	606 E Cindy ST Last Flow Test: 04/13/2018 1138 gpm		
0359	316 Birchlane DR Last Flow Test: 04/13/2018 1087 gpm	Elbow	
0360	300 Birchlane DR Last Flow Test: 04/13/2018 1087 gpm	Elbow	
0361	315 S Lynda ST Last Flow Test: 04/13/2018 1113 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0362	E Park ST Last Flow Test: 04/10/2018 168 gpm		
0363	E Park ST Last Flow Test: 05/16/2018 237 gpm		
0364	2100 Reed Station PKY Last Flow Test: 04/30/2018 1233 gpm	Elbow	
0365	2100 Reed Station PKY Last Flow Test: 04/30/2018 1233 gpm		
0366	2100 Reed Station PKY Last Flow Test: 04/30/2018 1233 gpm	Elbow	
0367	S Cedarview ST & E Walnut Last Flow Test: 04/13/2018 1138 gpm	Elbow	
0368	105 S Lewis LANE Last Flow Test: 05/10/2018 1186 gpm		
0369	1111 E Walnut ST Last Flow Test: 05/15/2018 1210 gpm	Elbow	
0370	219 S Lewis LN Last Flow Test: 05/16/2018 1163 gpm	Elbow	
0371	San Diego RD & County Line Last Flow Test: 05/15/2018 1061 gpm		
0372	239 S Lewis LN Last Flow Test: 05/16/2018 1233 gpm	Elbow	
0373	Glenn RD & New Era Last Flow Test: 05/11/2018 671 gpm	Elbow	
0374	351 S Lewis LANE Last Flow Test: 05/08/2018 1233 gpm		
0375	1101 E College ST Last Flow Test: 05/08/2018 1233 gpm		
0376	1101B E College ST Last Flow Test: 05/08/2018 1186 gpm		
0377	500A S Lewis LANE Last Flow Test: 04/12/2018 1163 gpm	Elbow	
0378	500B S Lewis LANE Last Flow Test: 04/12/2018 1061 gpm	Elbow	
0379	500C S Lewis LANE Last Flow Test: 04/12/2018 919 gpm		
0380	500D S Lewis LANE Last Flow Test: 04/12/2018 856 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0381	501 S Lewis LANE Last Flow Test: 05/08/2018 1163 gpm		
0382	601 S Lewis LANE Last Flow Test: 05/08/2018 1210 gpm		
0383	701 S Lewis LN Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0384	725 S Lewis LANE Last Flow Test: 05/07/2018 1087 gpm		
0385	700 S Lewis LANE Last Flow Test: 04/12/2018 1113 gpm	Elbow	
0386	202 S Lewis LANE & Fields Apartments Last Flow Test: 04/12/2018 1163 gpm	Elbow	
0387	502 N Fields Apartments Last Flow Test: 04/12/2018 1113 gpm	Elbow	
0388	1405 S Fields Apartments Last Flow Test: 04/12/2018 1163 gpm	Elbow	
0389	1207 Fields Apartments Last Flow Test: 04/12/2018 1087 gpm	Elbow	
0390	1001 E College ST Last Flow Test: 04/12/2018 1113 gpm		
0391	1000 E Grand AVE Last Flow Test: 04/12/2018 1007 gpm		
0392	801 S Lewis LANE Last Flow Test: 05/07/2018 888 gpm		
0393	800A E Grand AVE Last Flow Test: 04/12/2018 1186 gpm		
0394	800B E Grand AVE Last Flow Test: 04/12/2018 1163 gpm		
0395	800C E Grand AVE Last Flow Test: 04/12/2018 1087 gpm	Elbow	
0396	800D E Grand AVE Last Flow Test: 04/12/2018 1163 gpm	Elbow	
0397	800E E Grand AVE Last Flow Test: 04/12/2018 1113 gpm		
0398	800F E Grand AVE Last Flow Test: 04/12/2018 168 gpm	Elbow	
0399	760 E Grand AVE Last Flow Test: 04/12/2018 1061 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0400	603 E Grand AVE Last Flow Test: 04/12/2018 1278 gpm	Elbow	
0401	1129 E Rendleman ST Last Flow Test: 05/15/2018 237 gpm		
0402	301 S Lake Heights AVE Last Flow Test: 05/15/2018 531 gpm	Elbow	
0403	325 S Lake Heights AVE Last Flow Test: 05/16/2018 475 gpm		
0404	339 S Lake Heights AVE Last Flow Test: 05/16/2018 581 gpm	Elbow	
0405	1121 E College ST Last Flow Test: 05/16/2018 856 gpm	Elbow	
0406	207 S Hanseman ST Last Flow Test: 05/15/2018 531 gpm	Elbow	
0407	217 S Hanseman ST Last Flow Test: 05/15/2018 531 gpm	Elbow	
0408	313 S Hanseman ST Last Flow Test: 05/15/2018 531 gpm	Elbow	
0409	337 S Hanseman ST Last Flow Test: 05/15/2018 531 gpm		
0410	1181 E Walnut ST Last Flow Test: 05/15/2018 978 gpm		
0411	1195 E Walnut ST Last Flow Test: 05/15/2018 671 gpm	Elbow	
0412	1195B E Walnut ST Last Flow Test: 05/15/2018 411 gpm	Elbow	
0413	1195S E Walnut ST Last Flow Test: 05/15/2018 336 gpm		
0414	1201 E Walnut ST Last Flow Test: 05/15/2018 888 gpm		
0415	1215 E Walnut ST Last Flow Test: 05/15/2018 856 gpm	Elbow	
0416	1257 E Walnut ST Last Flow Test: 05/15/2018 856 gpm		
0417	1270 E Walnut ST Last Flow Test: 05/09/2018 856 gpm		
0418	1271 E Walnut ST Last Flow Test: 05/09/2018 856 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0419	1301 E Walnut ST Last Flow Test: 05/11/2018	822 gpm	
0420	100 S Giant City RD Last Flow Test: 05/11/2018	822 gpm	
0421	1271 E Main ST Last Flow Test: 05/10/2018	1061 gpm	
0422	1101 New Era RD Last Flow Test: 04/25/2018	822 gpm	Elbow
0423	1255 E Main ST Last Flow Test: 05/10/2018	1138 gpm	
0424	1191 New Era RD Last Flow Test: 04/25/2018	787 gpm	Elbow
0425	1201 S Giant City RD Last Flow Test: 05/02/2018	856 gpm	Elbow
0426	1241 E Main ST Last Flow Test: 05/10/2018	1210 gpm	Elbow
0427	1237 E Main ST Last Flow Test: 05/10/2018	1138 gpm	Elbow
0428	1201C E Main ST Last Flow Test: 05/10/2018	1278 gpm	
0429	1201A E Main ST Last Flow Test: 05/10/2018	1278 gpm	Elbow
0430	1215 E Main ST Last Flow Test: 05/10/2018	978 gpm	Elbow
0431	1161A E Main ST Last Flow Test: 05/10/2018	1256 gpm	Elbow
0432	1225 E Main ST Last Flow Test: 05/10/2018	1233 gpm	
0433	1265A E Main ST Last Flow Test: 05/10/2018	1186 gpm	
0434	2400 Reed Station PKY Last Flow Test: 04/30/2018	1233 gpm	
0435	908 S Lewis LN Last Flow Test: 04/10/2018	856 gpm	Elbow
0436	912 S Lewis LN Last Flow Test: 04/10/2018	787 gpm	
0437	1301C E Main ST Last Flow Test: 05/15/2018	919 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0438	1301A E Main ST Last Flow Test: 05/15/2018	1061 gpm	
0439	1303 E Main ST Last Flow Test: 05/15/2018	1087 gpm	
0440	1345 E Main ST Last Flow Test: 05/15/2018	1061 gpm	
0441	1385 E Main ST Last Flow Test: 05/15/2018	1087 gpm	
0442	1393 E Main ST Last Flow Test: 05/15/2018	1113 gpm	
0443	1395B E Main ST Last Flow Test: 05/15/2018	1087 gpm	
0444	1433 E Walnut ST Last Flow Test: 05/11/2018	750 gpm	
0445	1440 E Walnut ST Last Flow Test: 05/11/2018	856 gpm	
0446	1534 E Walnut ST Last Flow Test: 05/04/2018	712 gpm	
0447	1215 New Era RD Last Flow Test: 04/25/2018	787 gpm	Elbow
0448	222 S Giant City RD Last Flow Test: 05/09/2018	671 gpm	
0449	337 N Giant City RD Last Flow Test: 05/14/2018	919 gpm	Elbow
0450	226 S Hunt RD Last Flow Test: 05/15/2018	531 gpm	Elbow
0451	216 S Hunt RD Last Flow Test: 05/15/2018	671 gpm	
0452	609 S Giant City RD Last Flow Test: 05/08/2018	856 gpm	
0453	1321 E Meadowbrook LANE Last Flow Test: 05/08/2018	888 gpm	Elbow
0454	1317 E Meadowbrook LANE Last Flow Test: 05/08/2018	856 gpm	
0455	1201 Meadowbrook LN Last Flow Test: 05/08/2018	750 gpm	
0456	1330 E Grand AVE Last Flow Test: 05/08/2018	888 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0457	1541 E Grand AVE Last Flow Test: 05/08/2018 336 gpm	Elbow	
0458	1547 E Gary DR Last Flow Test: 05/08/2018 411 gpm	Elbow	
0459	1507 E Gary DR Last Flow Test: 05/08/2018 475 gpm		
0460	925 S Giant City RD Last Flow Test: 05/02/2018 949 gpm	Elbow	
0461	925 S Giant City RD Last Flow Test: 05/02/2018 822 gpm		
0462	1017 S Giant City RD Last Flow Test: 05/02/2018 978 gpm		
0463	1431 Dogwood RD Last Flow Test: 05/02/2018 1087 gpm	Elbow	
0464	1200A E Grand AVE Last Flow Test: 05/07/2018 949 gpm	Elbow	
0465	1200B E Grand AVE Last Flow Test: 05/07/2018 949 gpm		
0466	1200C E Grand AVE Last Flow Test: 05/07/2018 336 gpm	Elbow	
0467	1200D E Grand AVE Last Flow Test: 05/07/2018 856 gpm	Elbow	
0468	1200 E Grand AVE Last Flow Test: 05/07/2018 1007 gpm		
0469	1200F E Grand AVE Last Flow Test: 05/07/2018 1061 gpm		
0470	1245A E Grand AVE Last Flow Test: 05/04/2018 888 gpm		
0471	1245B E Grand AVE Last Flow Test: 05/04/2018 856 gpm	Elbow	
0472	1245C E Grand AVE Last Flow Test: 05/04/2018 787 gpm	Elbow	
0473	1245D E Grand AVE Last Flow Test: 05/04/2018 712 gpm		
0474	1000 E Park ST Last Flow Test: 04/10/2018 978 gpm		
0475	955 Villa CT Last Flow Test: 04/30/2018 671 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0476	1225 New Era RD Last Flow Test: 04/25/2018	787 gpm	
0477	624 E Campus DR Last Flow Test: 04/09/2018	787 gpm	
0478	1167A S Glenbeth DR Last Flow Test: 04/09/2018	822 gpm	Elbow
0479	1251 New Era RD Last Flow Test: 04/25/2018	712 gpm	
0480	1147 S Glenbeth DR Last Flow Test: 04/09/2018	822 gpm	Elbow
0481	1130 S Morningside DR Last Flow Test: 04/09/2018	750 gpm	Elbow
0482	1207A S Wall ST Last Flow Test: 04/16/2018	978 gpm	Elbow
0483	1207D S Wall ST Last Flow Test: 04/16/2018	949 gpm	Elbow
0484	1207C S Wall ST Last Flow Test: 04/16/2018	978 gpm	Elbow
0485	1207B S Wall ST Last Flow Test: 04/16/2018	712 gpm	Elbow
0486	890 S Wall ST Last Flow Test: 04/16/2018	1210 gpm	Elbow
0487	1275 New Era RD Last Flow Test: 04/25/2018	750 gpm	Elbow
0488	1591 New Era RD Last Flow Test: 04/26/2018	888 gpm	Elbow
0489	1731 New Era RD Last Flow Test: 04/26/2018	787 gpm	
0490	900 S Illinois AVE Last Flow Test: 04/09/2018	1007 gpm	Elbow
0491	824 S Illinois AVE Last Flow Test: 04/09/2018	949 gpm	Elbow
0492	800 S Illinois AVE Last Flow Test: 04/09/2018	978 gpm	Elbow
0493	718 S Illinois AVE Last Flow Test: 04/09/2018	978 gpm	Elbow
0494	700 S Illinois AVE Last Flow Test: 04/09/2018	978 gpm	Elbow

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0495	208 W Freeman ST Last Flow Test: 04/09/2018 237 gpm	Elbow	
0496	600 S Illinois AVE Last Flow Test: 04/09/2018 1061 gpm	Elbow	
0497	514 S Illinois AVE Last Flow Test: 04/11/2018 978 gpm	Elbow	
0498	500 S Illinois AVE Last Flow Test: 04/11/2018 978 gpm	Elbow	
0499	400 S Illinois AVE Last Flow Test: 04/11/2018 856 gpm	Elbow	
0500	300 S Illinois AVE Last Flow Test: 04/17/2018 856 gpm		
0501	330 S Hunt RD Last Flow Test: 05/15/2018 671 gpm		
0502	200 S Illinois AVE Last Flow Test: 04/17/2018 856 gpm		
0503	204 S University AVE Last Flow Test: 04/17/2018 822 gpm		
0504	300 S University AVE Last Flow Test: 04/17/2018 919 gpm	Elbow	
0505	200 W Elm ST Last Flow Test: 04/11/2018 787 gpm	Elbow	
0506	502 S University AVE Last Flow Test: 04/11/2018 750 gpm		
0507	210 W College ST Last Flow Test: 04/09/2018 1034 gpm	Elbow	
0508	712 S University AVE Last Flow Test: 04/09/2018 949 gpm		
0509	901 Normal AVE Last Flow Test: 05/11/2018 411 gpm	Elbow	
0510	912 Normal AVE Last Flow Test: 05/11/2018 237 gpm	Elbow	
0511	401 W Grand AVE Last Flow Test: 05/11/2018 856 gpm	Elbow	
0512	1000 Faner DR Last Flow Test: 05/11/2018 628 gpm	Elbow	
0513	501 W Grand AVE Last Flow Test: 05/11/2018 949 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0514	601 W Grand AVE Last Flow Test: 05/11/2018	919 gpm	
0515	701 W Grand AVE Last Flow Test: 05/11/2018	787 gpm	Elbow
0516	801 W Grand AVE Last Flow Test: 05/11/2018	0 gpm	
0517	610 S Thompson ST Last Flow Test: 04/09/2018	949 gpm	Elbow
0518	510 S Ash ST Last Flow Test: 04/11/2018	581 gpm	
0519	410 S Ash ST Last Flow Test: 04/11/2018	822 gpm	
0520	1775 New Era RD Last Flow Test: 04/26/2018	750 gpm	
0521	323 W Walnut ST Last Flow Test: 04/17/2018	628 gpm	
0522	305 S Beveridge ST Last Flow Test: 04/11/2018	531 gpm	
0523	409 S Beveridge ST Last Flow Test: 04/11/2018	787 gpm	
0524	500 W College ST Last Flow Test: 04/10/2018	712 gpm	Elbow
0525	400 W Mill ST Last Flow Test: 04/10/2018	919 gpm	Elbow
0526	600 W Mill ST Last Flow Test: 04/10/2018	237 gpm	Elbow
0527	701 S Poplar ST Last Flow Test: 04/10/2018	750 gpm	Elbow
0528	2801 W Kent DR Last Flow Test: 05/08/2018	856 gpm	Elbow
0529	411 S Poplar ST Last Flow Test: 04/11/2018	888 gpm	
0530	501 W Walnut ST Last Flow Test: 04/17/2018	949 gpm	
0531	411 W Monroe ST Last Flow Test: 04/17/2018	581 gpm	Elbow
0532	501 W Main ST Last Flow Test: 04/18/2018	475 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0533	110 S Maple ST Last Flow Test: 04/18/2018 822 gpm	Elbow	
0534	513 W Walnut ST Last Flow Test: 04/11/2018 888 gpm	Elbow	
0535	615 W Elm ST Last Flow Test: 04/11/2018 581 gpm		
0536	703 S Rawlings ST Last Flow Test: 04/10/2018 671 gpm		
0537	701 S Rawlings ST Last Flow Test: 04/10/2018 750 gpm	Elbow	
0538	613 W College ST Last Flow Test: 04/11/2018 822 gpm		
0539	701 W Cherry ST Last Flow Test: 04/11/2018 787 gpm		
0540	504 S Hays ST Last Flow Test: 04/11/2018 336 gpm		
0541	516 S Hays ST Last Flow Test: 04/11/2018 822 gpm	Elbow	
0542	800 W Freeman ST Last Flow Test: 04/10/2018 919 gpm	Elbow	
0543	707 W Mill ST Last Flow Test: 05/14/2018 1061 gpm		
0544	810 W Mill ST Last Flow Test: 04/10/2018 888 gpm	Elbow	
0545	813 S Forest AVE Last Flow Test: 05/14/2018 949 gpm		
0546	W Mill ST & S Forest Last Flow Test: 04/10/2018 750 gpm	Elbow	
0547	705 S Forest AVE Last Flow Test: 04/10/2018 787 gpm	Elbow	
0548	810 W College ST Last Flow Test: 04/11/2018 787 gpm	Elbow	
0549	808 W Schwartz ST Last Flow Test: 05/15/2018 1007 gpm	Elbow	
0550	410 S Forest AVE Last Flow Test: 04/10/2018 411 gpm	Elbow	
0551	400 S Forest AVE Last Flow Test: 04/11/2018 978 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0552	801 W Walnut ST Last Flow Test: 04/11/2018 949 gpm	Elbow	
0553	114 S Forest AVE Last Flow Test: 04/18/2018 237 gpm		
0554	811 W Main ST Last Flow Test: 05/14/2018 411 gpm		
0555	811 W Walnut ST Last Flow Test: 04/11/2018 919 gpm	Elbow	
0556	409 S James ST Last Flow Test: 04/10/2018 411 gpm	Elbow	
0557	1000 W Cherry ST Last Flow Test: 04/10/2018 581 gpm	Elbow	
0558	511 S James ST Last Flow Test: 04/10/2018 531 gpm	Elbow	
0559	701 S James ST Last Flow Test: 04/10/2018 712 gpm		
0560	801 S Elizabeth ST Last Flow Test: 04/10/2018 822 gpm	Elbow	
0561	912 Elizabeth ST Last Flow Test: 05/14/2018 411 gpm		
0562	1010 S Elizabeth ST Last Flow Test: 05/14/2018 1034 gpm		
0563	1006 W Chautauqua ST Last Flow Test: 05/14/2018 531 gpm		
0564	913 S Oakland AVE Last Flow Test: 05/14/2018 168 gpm		
0565	920 E Walnut ST Last Flow Test: 04/17/2018 978 gpm	Elbow	
0566	613 S Oakland AVE Last Flow Test: 04/10/2018 581 gpm	Elbow	
0567	W Schwartz ST Last Flow Test: 05/15/2018 856 gpm	Elbow	
0568	317 S Oakland AVE Last Flow Test: 04/11/2018 475 gpm		
0569	821 W Walnut ST Last Flow Test: 04/11/2018 919 gpm		
0570	1825 New Era RD Last Flow Test: 04/26/2018 787 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0571	1891 New Era RD Last Flow Test: 04/26/2018	787 gpm	
0572	310 W Walnut ST Last Flow Test: 04/17/2018	787 gpm	
0573	110 S Brook LANE Last Flow Test: 04/17/2018	856 gpm	
0574	212 S Brook LANE Last Flow Test: 04/17/2018	750 gpm	
0575	930 W Walnut ST Last Flow Test: 04/17/2018	856 gpm	
0576	300 S Oakland AVE Last Flow Test: 04/17/2018	750 gpm	
0577	1212 W Schwartz ST Last Flow Test: 04/12/2018	750 gpm	
0578	302 S Eason DR Last Flow Test: 04/12/2018	978 gpm	Elbow
0579	504 S Eason DR Last Flow Test: 04/12/2018	712 gpm	
0580	1307 W Schwartz ST Last Flow Test: 04/12/2018	750 gpm	
0581	512 S Orchard DR Last Flow Test: 04/12/2018	581 gpm	
0582	503 S Orchard DR Last Flow Test: 04/17/2018	237 gpm	
0583	403 S Orchard DR Last Flow Test: 04/17/2018	475 gpm	
0584	301 S Orchard DR Last Flow Test: 04/17/2018	237 gpm	
0585	200 S Orchard DR Last Flow Test: 04/17/2018	581 gpm	
0586	705 W Cherry ST Last Flow Test: 04/11/2018	856 gpm	
0587	1217 W Main ST Last Flow Test: 04/20/2018	1034 gpm	
0588	203 S Friedline DR Last Flow Test: 04/17/2018	712 gpm	Elbow
0589	211 S Friedline DR Last Flow Test: 04/17/2018	787 gpm	Elbow

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0590	305 S Friedline DR Last Flow Test: 04/17/2018 856 gpm	Elbow	
0591	110 S Dixon AVE Last Flow Test: 04/17/2018 856 gpm	Elbow	
0592	304 S Dixon AVE Last Flow Test: 04/17/2018 856 gpm	Elbow	
0593	502 S Dixon AVE Last Flow Test: 04/12/2018 822 gpm		
0594	608 S Dixon AVE Last Flow Test: 04/12/2018 628 gpm		
0595	1220 W Freeman ST Last Flow Test: 04/10/2018 628 gpm		
0596	703 S Murrie DR Last Flow Test: 05/14/2018 531 gpm		
0597	1218 W Freeman ST Last Flow Test: 04/10/2018 531 gpm	Elbow	
0598	1208 W Freeman ST Last Flow Test: 04/10/2018 475 gpm	Elbow	
0599	702 S Benwood DR Last Flow Test: 04/10/2018 475 gpm	Elbow	
0600	1105 W College ST Last Flow Test: 04/12/2018 531 gpm		
0601	1207 W College ST Last Flow Test: 04/12/2018 411 gpm		
0602	1216 W College ST Last Flow Test: 04/12/2018 411 gpm	Elbow	
0603	1010 W Walkup AVE Last Flow Test: 04/10/2018 787 gpm	Elbow	
0604	1122 W Walkup AVE Last Flow Test: 05/14/2018 712 gpm	Elbow	
0605	1130 W Walkup AVE Last Flow Test: 05/14/2018 0 gpm		
0606	1217 W Carter ST Last Flow Test: 05/14/2018 750 gpm	Elbow	
0607	1100 W Carter ST Last Flow Test: 04/10/2018 628 gpm	Elbow	
0608	906 W Carter ST Last Flow Test: 04/10/2018 531 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0609	912 S Johnson AVE Last Flow Test: 04/10/2018 787 gpm	Elbow	
0610	1113 W Chautauqua ST Last Flow Test: 05/11/2018 978 gpm		
0611	1202 W Chautauqua ST Last Flow Test: 04/09/2018 750 gpm	Elbow	
0612	1215 W Chautauqua ST Last Flow Test: 05/11/2018 750 gpm		
0613	1220 W Chautauqua ST Last Flow Test: 04/09/2018 712 gpm		
0614	1401 Chautauqua ST Last Flow Test: 05/11/2018 787 gpm		
0615	1306 W Chautauqua ST Last Flow Test: 04/09/2018 712 gpm		
0616	900 S Valley RD Last Flow Test: 04/10/2018 531 gpm	Elbow	
0617	914 S Taylor DR Last Flow Test: 04/10/2018 581 gpm	Elbow	
0618	904 S Taylor DR Last Flow Test: 04/10/2018 581 gpm	Elbow	
0619	808 S Taylor DR Last Flow Test: 04/10/2018 628 gpm	Elbow	
0620	1302 W Freeman ST Last Flow Test: 04/10/2018 750 gpm	Elbow	
0621	1402 W Freeman ST Last Flow Test: 04/10/2018 712 gpm	Elbow	
0622	702 S Taylor DR Last Flow Test: 04/12/2018 628 gpm		
0623	1403 W Taylor DR Last Flow Test: 04/12/2018 581 gpm		
0624	1009 S Skyline DR Last Flow Test: 04/09/2018 475 gpm	Elbow	
0625	909 S Skyline DR Last Flow Test: 04/10/2018 475 gpm	Elbow	
0626	809 S Skyline DR Last Flow Test: 04/10/2018 475 gpm	Elbow	
0627	803 S Skyline DR Last Flow Test: 04/10/2018 531 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0628	615 S Skyline DR Last Flow Test: 04/12/2018 628 gpm		
0629	601 S Skyline DR Last Flow Test: 04/12/2018 628 gpm		
0630	407 S Skyline DR Last Flow Test: 04/12/2018 628 gpm		
0631	200 S Travelstead LANE Last Flow Test: 04/17/2018 787 gpm		
0632	1401 W Walnut ST Last Flow Test: 04/17/2018 671 gpm		
0633	1402 W Walnut ST Last Flow Test: 04/17/2018 750 gpm		
0634	201 S Pine LANE Last Flow Test: 04/17/2018 822 gpm		
0635	211 S Hewitt ST Last Flow Test: 04/17/2018 628 gpm		
0636	201 S Hewitt ST Last Flow Test: 04/17/2018 712 gpm		
0637	1505 W Tripoli ST Last Flow Test: 04/17/2018 712 gpm		
0638	1425 W Old Main ST Last Flow Test: 04/18/2018 750 gpm		
0639	1425E W Old Main ST Last Flow Test: 04/18/2018 949 gpm	Elbow	
0640	1425N W Old Main ST Last Flow Test: 04/18/2018 1138 gpm	Elbow	
0641	1425S W Old Main ST Last Flow Test: 04/18/2018 1138 gpm	Elbow	
0642	107 N Glenview DR Last Flow Test: 04/19/2018 1007 gpm	Elbow	
0643	3108 W Kent DR Last Flow Test: 05/04/2018 750 gpm	Elbow	
0644	107 S Glenview DR Last Flow Test: 05/14/2018 978 gpm	Elbow	
0645	113 S Glenview DR Last Flow Test: 04/18/2018 919 gpm	Elbow	
0646	301 S Glenview DR Last Flow Test: 04/18/2018 750 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0647	600 S Glenview DR Last Flow Test: 04/12/2018	750 gpm	
0648	1504 W Taylor DR Last Flow Test: 04/12/2018	581 gpm	
0649	608 S Glenview DR Last Flow Test: 04/12/2018	750 gpm	
0650	618 S Glenview DR Last Flow Test: 04/12/2018	822 gpm	
0651	1600 W Freeman ST Last Flow Test: 04/10/2018	856 gpm	Elbow
0652	903 S Glenview DR Last Flow Test: 04/10/2018	671 gpm	Elbow
0653	1001 S Glenview DR Last Flow Test: 04/10/2018	531 gpm	Elbow
0654	1021 S Glenview DR Last Flow Test: 04/09/2018	475 gpm	
0655	1019 S Briarwood DR Last Flow Test: 04/09/2018	531 gpm	
0656	1005 S Briarwood DR Last Flow Test: 04/09/2018	628 gpm	Elbow
0657	903 S Briarwood DR Last Flow Test: 04/09/2018	712 gpm	Elbow
0658	1 Hillcrest DR Last Flow Test: 04/09/2018	531 gpm	
0659	11 Hillcrest DR Last Flow Test: 04/09/2018	475 gpm	Elbow
0660	30 Hillcrest DR Last Flow Test: 04/09/2018	531 gpm	Elbow
0661	48 Hillcrest DR Last Flow Test: 04/09/2018	671 gpm	
0662	1031 S Emerald LN Last Flow Test: 04/09/2018	1034 gpm	Elbow
0663	1007 S Emerald LN Last Flow Test: 04/09/2018	671 gpm	Elbow
0664	807 S Emerald LN Last Flow Test: 04/09/2018	787 gpm	Elbow
0665	1605 W Freeman ST Last Flow Test: 04/09/2018	822 gpm	Elbow

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0666	1801 W Freeman ST Last Flow Test: 04/09/2018 856 gpm	Elbow	
0667	2005 W Freeman ST Last Flow Test: 04/09/2018 581 gpm		
0668	620 S Surrey LANE Last Flow Test: 04/12/2018 750 gpm		
0669	606 S Wedgewood LANE Last Flow Test: 04/12/2018 787 gpm		
0670	622 S Wedgewood LANE Last Flow Test: 04/12/2018 787 gpm		
0671	616 S Terrace DR Last Flow Test: 04/12/2018 822 gpm		
0672	1704 W Taylor DR Last Flow Test: 04/12/2018 856 gpm		
0673	1712 W Colonial DR Last Flow Test: 04/18/2018 1061 gpm	Elbow	
0674	1803 W Walnut ST Last Flow Test: 04/18/2018 1163 gpm	Elbow	
0675	208 Canterbury DR Last Flow Test: 04/19/2018 822 gpm	Elbow	
0676	208 S Wedgewood LANE Last Flow Test: 04/18/2018 1163 gpm	Elbow	
0677	1810 W Sunset DR Last Flow Test: 04/19/2018 1034 gpm	Elbow	
0678	1736 Old West Main ST Last Flow Test: 04/19/2018 1007 gpm	Elbow	
0679	1902 W Old Main ST Last Flow Test: 04/19/2018 531 gpm	Elbow	
0680	105 N Emerald LN Last Flow Test: 04/19/2018 856 gpm	Elbow	
0681	1809 W Main ST Last Flow Test: 04/19/2018 336 gpm	Elbow	
0682	2001 W Main ST Last Flow Test: 04/20/2018 411 gpm		
0683	2018C W Woodriver Last Flow Test: 04/20/2018 237 gpm		
0684	2020C W Woodriver Last Flow Test: 04/20/2018 336 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0685	2106 W Woodriver Last Flow Test: 04/20/2018	978 gpm	
0686	2020A W Woodriver Last Flow Test: 04/20/2018	750 gpm	
0687	2018A W Woodriver Last Flow Test: 04/20/2018	888 gpm	
0688	2004 W Woodriver Last Flow Test: 04/20/2018	978 gpm	
0689	701 S Emerald LN Last Flow Test: 04/12/2018	628 gpm	Elbow
0690	503 S Emerald LN Last Flow Test: 04/12/2018	581 gpm	Elbow
0691	2007 W Norwood DR Last Flow Test: 04/12/2018	411 gpm	
0692	403 S Emerald LANE Last Flow Test: 04/20/2018	336 gpm	
0693	305 S Emerald LANE Last Flow Test: 04/20/2018	336 gpm	Elbow
0694	219 S Emerald LANE Last Flow Test: 04/20/2018	336 gpm	
0695	209 S Emerald LANE Last Flow Test: 04/20/2018	336 gpm	Elbow
0696	1905 W Sunset DR Last Flow Test: 04/20/2018	475 gpm	
0697	2010 W Sunset DR Last Flow Test: 04/20/2018	531 gpm	Elbow
0698	207 S Gray DR Last Flow Test: 04/20/2018	475 gpm	Elbow
0699	217 S Gray DR Last Flow Test: 04/20/2018	531 gpm	Elbow
0700	2004 W Meadow LN Last Flow Test: 04/20/2018	411 gpm	Elbow
0701	309 E Plover DR Last Flow Test: 04/20/2018	475 gpm	Elbow
0702	303 E Plover DR Last Flow Test: 04/20/2018	475 gpm	Elbow
0703	2108 N Partridge LANE Last Flow Test: 04/20/2018	475 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0704	2100 W Sunset DR Last Flow Test: 04/20/2018 475 gpm	Elbow	
0705	2108 W Sunset DR Last Flow Test: 04/20/2018 475 gpm	Elbow	
0706	2501 W Sunset DR Last Flow Test: 05/11/2018 919 gpm		
0707	2500 W Chautauqua ST Last Flow Test: 04/30/2018 628 gpm		
0708	2800 W Chautauqua ST Last Flow Test: 04/30/2018 888 gpm	Elbow	
0709	955 S Tower RD Last Flow Test: 04/30/2018 888 gpm	Elbow	
0710	901 S Tower RD Last Flow Test: 04/30/2018 888 gpm	Elbow	
0711	807 S Tower RD Last Flow Test: 04/30/2018 919 gpm	Elbow	
0712	701 S Tower RD Last Flow Test: 04/30/2018 888 gpm	Elbow	
0713	601 S Tower RD Last Flow Test: 04/30/2018 888 gpm	Elbow	
0714	501 S Tower RD Last Flow Test: 04/30/2018 888 gpm	Elbow	
0715	32 Pinewood DR Last Flow Test: 05/01/2018 919 gpm	Elbow	
0716	26 Pinewood DR Last Flow Test: 05/01/2018 787 gpm	Elbow	
0717	22 Pinewood DR Last Flow Test: 05/01/2018 822 gpm	Elbow	
0718	12 Pinewood DR Last Flow Test: 04/30/2018 671 gpm		
0719	8 Pinewood DR Last Flow Test: 04/30/2018 581 gpm	Elbow	
0720	307 S Tower RD Last Flow Test: 05/01/2018 919 gpm	Elbow	
0721	1000 N Almond ST Last Flow Test: 04/24/2018 949 gpm	Elbow	
0722	2615 W Kent DR Last Flow Test: 05/08/2018 919 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0723	101 S Parrish LN Last Flow Test: 05/08/2018 949 gpm		
0724	109 S Rod LN Last Flow Test: 05/08/2018 581 gpm		
0725	2706 W Sunset DR Last Flow Test: 05/08/2018 822 gpm	Elbow	
0726	124 Parrish LN Last Flow Test: 05/11/2018 888 gpm		
0727	206 Parrish LN Last Flow Test: 05/11/2018 919 gpm		
0728	2601 Murphysboro RD Last Flow Test: 05/11/2018 1034 gpm		
0729	2701 Murphysboro RD Last Flow Test: 05/11/2018 1034 gpm		
0730	208 Lark LN Last Flow Test: 05/11/2018 1007 gpm	Elbow	
0731	120 Lark LN Last Flow Test: 05/11/2018 888 gpm		
0732	102 Lark LN Last Flow Test: 05/11/2018 919 gpm		
0733	2906 Kent DR Last Flow Test: 05/07/2018 919 gpm	Elbow	
0734	3100 Kent DR Last Flow Test: 05/04/2018 787 gpm	Elbow	
0735	3204 Kent DR Last Flow Test: 05/04/2018 750 gpm	Elbow	
0736	324 W Lu CT Last Flow Test: 05/04/2018 750 gpm	Elbow	
0737	123 S Violet LN Last Flow Test: 05/07/2018 822 gpm	Elbow	
0738	219 Mark CT Last Flow Test: 05/07/2018 628 gpm	Elbow	
0739	106 Mark CT Last Flow Test: 05/07/2018 750 gpm	Elbow	
0740	106 S Violet LN Last Flow Test: 05/07/2018 750 gpm	Elbow	
0741	2998 W Sunset DR Last Flow Test: 05/07/2018 919 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0742	2945 W Sunset DR Last Flow Test: 05/07/2018 949 gpm		
0743	208 Tower RD Last Flow Test: 05/08/2018 888 gpm	Elbow	
0744	202 Tower RD Last Flow Test: 05/08/2018 888 gpm		
0745	110 Tower RD Last Flow Test: 05/08/2018 856 gpm	Elbow	
0746	104 Tower RD Last Flow Test: 05/08/2018 888 gpm	Elbow	
0747	2900 W Sunset DR Last Flow Test: 05/08/2018 712 gpm		
0748	110 Tower RD Last Flow Test: 05/08/2018 978 gpm		
0749	207 Tower RD Last Flow Test: 05/08/2018 949 gpm		
0750	220 Tower RD Last Flow Test: 05/08/2018 1007 gpm		
0751	200 Tower RD Last Flow Test: 05/08/2018 978 gpm		
0752	1945 New Era RD Last Flow Test: 04/26/2018 750 gpm		
0753	2801D Murphysboro RD Last Flow Test: 05/11/2018 1034 gpm	Elbow	
0754	2801B Murphysboro RD Last Flow Test: 05/11/2018 712 gpm		
0755	2411A W Main ST Last Flow Test: 05/10/2018 787 gpm		
0756	2411B W Main ST Last Flow Test: 05/10/2018 787 gpm		
0757	2499A W Main ST Last Flow Test: 05/10/2018 919 gpm		
0758	2431A W Main ST Last Flow Test: 05/10/2018 919 gpm		
0759	2421A W Main ST Last Flow Test: 05/10/2018 919 gpm		
0760	2421C W Main ST Last Flow Test: 05/10/2018 919 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0761	2516 W Murphysboro RD Last Flow Test: 05/10/2018 888 gpm	Elbow	
0762	2431C W Main ST Last Flow Test: 05/10/2018 919 gpm		
0763	2499C W Main ST Last Flow Test: 05/10/2018 856 gpm		
0764	306 W College ST Last Flow Test: 04/10/2018 822 gpm	Elbow	
0765	2601C W Main ST Last Flow Test: 05/09/2018 712 gpm	Elbow	
0766	1001 Beadle DR Last Flow Test: 05/11/2018 822 gpm		
0767	809 Beadle DR Last Flow Test: 05/09/2018 919 gpm		
0768	414 Beadle DR Last Flow Test: 05/09/2018 787 gpm		
0769	380 Beadle DR Last Flow Test: 05/09/2018 822 gpm		
0770	500 N Westridge DR Last Flow Test: 05/09/2018 531 gpm	Elbow	
0771	2001 New Era RD Last Flow Test: 04/26/2018 750 gpm		
0772	400 N Westridge DR Last Flow Test: 05/09/2018 750 gpm	Elbow	
0773	401 N Westridge DR Last Flow Test: 05/15/2018 822 gpm		
0774	315 N Westridge DR Last Flow Test: 05/15/2018 888 gpm		
0775	2901 W Murphysboro RD Last Flow Test: 05/11/2018 1034 gpm	Elbow	
0776	500 N Robinson CIR Last Flow Test: 05/09/2018 750 gpm	Elbow	
0777	2601A W Main ST Last Flow Test: 05/09/2018 712 gpm		
0778	2513 W Murphysboro RD Last Flow Test: 05/11/2018 1163 gpm	Elbow	
0779	2421B W Main ST Last Flow Test: 05/10/2018 671 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0780	2975 Striegel RD Last Flow Test: 05/10/2018 671 gpm	Elbow	
0781	601 New Era RD Last Flow Test: 04/25/2018 787 gpm		
0782	701 New Era RD Last Flow Test: 04/25/2018 750 gpm		
0783	2051 New Era RD Last Flow Test: 04/26/2018 712 gpm		
0784	1003 Jefferson ST Last Flow Test: 04/20/2018 1087 gpm	Elbow	
0785	625 N Oakland AVE Last Flow Test: 04/23/2018 978 gpm		
0786	622 N Almond ST Last Flow Test: 04/23/2018 1007 gpm		
0787	315 W Willow ST Last Flow Test: 04/23/2018 1113 gpm		
0788	600 W Main ST Last Flow Test: 04/18/2018 856 gpm	Elbow	
0789	900 N Illinois AVE Last Flow Test: 05/14/2018 1061 gpm		
0790	1100 N Illinois AVE Last Flow Test: 04/26/2018 1087 gpm		
0791	1220 N Illinois AVE Last Flow Test: 04/26/2018 949 gpm	Elbow	
0792	1555 New Era RD Last Flow Test: 04/25/2018 750 gpm	Elbow	
0793	200 N Almond ST Last Flow Test: 04/18/2018 856 gpm	Elbow	
0794	415 N Brush ST Last Flow Test: 04/24/2018 1210 gpm	Elbow	
0795	100 N Illinois AVE Last Flow Test: 04/17/2018 1113 gpm		
0796	303 S Washington ST Last Flow Test: 04/19/2018 1113 gpm		
0797	200 E Walnut ST Last Flow Test: 04/20/2018 1256 gpm		
0798	313 E Walnut ST Last Flow Test: 04/20/2018 1256 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0799	511 E Walnut ST Last Flow Test: 04/20/2018 1300 gpm	Elbow	
0800	830 E College ST Last Flow Test: 04/13/2018 1034 gpm		
0801	901 E College ST Last Flow Test: 04/13/2018 1061 gpm		
0802	New Era RD & Charles Last Flow Test: 04/26/2018 712 gpm		
0803	701 W Chautauqua ST Last Flow Test: 05/14/2018 888 gpm		
0804	600 S Surrey LANE Last Flow Test: 04/12/2018 787 gpm		
0805	610 S Tower RD Last Flow Test: 04/30/2018 856 gpm	Elbow	
0806	2904 W Alveria DR Last Flow Test: 04/30/2018 787 gpm	Elbow	
0807	1110 Cedar CT Last Flow Test: 04/27/2018 787 gpm		
0808	1220 Cedar CT Last Flow Test: 04/27/2018 750 gpm		
0809	1300 Cedar CT Last Flow Test: 04/27/2018 750 gpm		
0810	1170 Cedar CT Last Flow Test: 04/27/2018 750 gpm		
0811	1111 Cedar CT Last Flow Test: 04/27/2018 671 gpm		
0812	1100 W Sycamore ST Last Flow Test: 04/20/2018 1113 gpm	Elbow	
0813	318 N Illinois AVE Last Flow Test: 04/17/2018 1087 gpm		
0814	411 N Illinois AVE Last Flow Test: 05/14/2018 1061 gpm		
0815	1111 E Walnut ST Last Flow Test: 05/16/2018 1061 gpm	Elbow	
0816	310 S Giant City RD Last Flow Test: 05/11/2018 1113 gpm		
0817	200 S Giant City RD Last Flow Test: 05/11/2018 1163 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0818	200 N Giant City RD Last Flow Test: 05/15/2018 1163 gpm		
0819	300 N Giant City RD Last Flow Test: 05/15/2018 1186 gpm		
0820	400 N Giant City RD Last Flow Test: 05/10/2018 1278 gpm		
0821	501 N Giant City RD Last Flow Test: 05/15/2018 1278 gpm	Elbow	
0822	600 N Giant City RD Last Flow Test: 05/15/2018 1113 gpm	Elbow	
0823	701 N Giant City RD Last Flow Test: 05/15/2018 1210 gpm	Elbow	
0824	801 N Giant City RD Last Flow Test: 05/15/2018 1300 gpm	Elbow	
0825	500 E Walnut ST Last Flow Test: 04/20/2018 1186 gpm	Elbow	
0826	630 N Oakland AVE Last Flow Test: 05/14/2018 888 gpm	Elbow	
0827	1001 N Oakland AVE Last Flow Test: 05/14/2018 978 gpm		
0828	1115 N Oakland AVE Last Flow Test: 05/14/2018 978 gpm		
0829	2100 New Era RD Last Flow Test: 04/26/2018 750 gpm		
0830	2401 McLafferty RD Last Flow Test: 05/11/2018 1061 gpm		
0831	2910 W Alveria DR Last Flow Test: 05/01/2018 888 gpm	Elbow	
0832	801 New Era RD Last Flow Test: 04/25/2018 750 gpm		
0833	880 New Era RD Last Flow Test: 04/25/2018 750 gpm		
0834	950 New Era RD Last Flow Test: 04/25/2018 856 gpm		
0835	306 E College ST Last Flow Test: 04/19/2018 1210 gpm		
0836	2451 Striegel RD Last Flow Test: 04/27/2018 750 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0837	2501 Striegel RD Last Flow Test: 04/27/2018 856 gpm		
0838	2575 Striegel RD Last Flow Test: 04/27/2018 671 gpm	Elbow	
0839	903 Norwest LN Last Flow Test: 04/27/2018 822 gpm		
0840	1000 Beadle DR Last Flow Test: 05/10/2018 750 gpm	Elbow	
0841	900 Beadle DR Last Flow Test: 05/10/2018 750 gpm	Elbow	
0842	808 Beadle DR Last Flow Test: 05/10/2018 671 gpm	Elbow	
0843	606 S Beadle DR Last Flow Test: 05/10/2018 750 gpm		
0844	844 Beadle DR Last Flow Test: 05/09/2018 750 gpm		
0845	514 Beadle DR Last Flow Test: 05/09/2018 856 gpm		
0846	205 W Chestnut ST Last Flow Test: 04/19/2018 888 gpm	Elbow	
0847	1630 E Walnut ST Last Flow Test: 05/04/2018 628 gpm		
0848	1416 E Grand AVE Last Flow Test: 05/08/2018 475 gpm	Elbow	
0849	1444 E Grand AVE Last Flow Test: 05/08/2018 336 gpm		
0850	600 E Campus DR Last Flow Test: 04/13/2018 787 gpm	Elbow	
0851	14D E Campus DR Last Flow Test: 04/13/2018 787 gpm	Elbow	
0852	8D E Campus DR Last Flow Test: 04/13/2018 822 gpm	Elbow	
0853	11D E Campus DR Last Flow Test: 04/13/2018 888 gpm	Elbow	
0854	6B E Campus DR Last Flow Test: 04/13/2018 856 gpm	Elbow	
0855	1007 E Park ST Last Flow Test: 05/16/2018 822 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0856	1005 E Park ST Last Flow Test: 04/10/2018 949 gpm	Elbow	
0857	1180 E Main ST Last Flow Test: 05/10/2018 1186 gpm	Elbow	
0858	1900 W Sycamore ST Last Flow Test: 04/24/2018 1113 gpm	Elbow	
0859	1601 W Sycamore ST Last Flow Test: 04/24/2018 1138 gpm		
0860	1004 W Sycamore ST Last Flow Test: 04/20/2018 1163 gpm	Elbow	
0861	911 W Sycamore ST Last Flow Test: 04/23/2018 949 gpm		
0862	1400C E Main ST Last Flow Test: 05/09/2018 1186 gpm		
0863	1396 E Main ST Last Flow Test: 05/09/2018 1138 gpm		
0864	E Main ST Last Flow Test: 05/09/2018 1138 gpm	Elbow	
0865	1322 E Main ST Last Flow Test: 05/09/2018 1007 gpm	Elbow	
0866	1328 E Main ST Last Flow Test: 05/09/2018 787 gpm	Elbow	
0867	1354 E Main ST Last Flow Test: 05/09/2018 1163 gpm	Elbow	
0868	1370A E Main ST Last Flow Test: 05/09/2018 1186 gpm	Elbow	
0869	1370C E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0870	1346 E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0871	1320 E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0872	618 E Campus DR Last Flow Test: 04/09/2018 856 gpm	Elbow	
0873	612D E Campus DR Last Flow Test: 04/09/2018 888 gpm		
0874	612B E Campus DR Last Flow Test: 04/09/2018 888 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0875	2701D W Main ST Last Flow Test: 05/09/2018 712 gpm		
0876	2701B W Main ST Last Flow Test: 05/16/2018 787 gpm		
0877	800 E Grand AVE Last Flow Test: 04/12/2018 1087 gpm		
0878	899 E Grand AVE Last Flow Test: 04/10/2018 1186 gpm	Elbow	
0879	2118 W Sunset DR Last Flow Test: 04/20/2018 475 gpm	Elbow	
0880	2152 W Ramada LANE Last Flow Test: 04/25/2018 712 gpm		
0881	2150 W Ramada LANE Last Flow Test: 04/25/2018 750 gpm	Elbow	
0882	3006 W Sunset DR Last Flow Test: 05/07/2018 750 gpm	Elbow	
0883	1000 Cedar CT Last Flow Test: 04/27/2018 712 gpm		
0884	2600 W Chautauqua ST Last Flow Test: 04/27/2018 531 gpm	Elbow	
0885	1009 Candletree DR Last Flow Test: 04/27/2018 475 gpm		
0886	1301 W Main ST Last Flow Test: 04/20/2018 978 gpm	Elbow	
0887	1511 W Main ST Last Flow Test: 04/18/2018 1138 gpm	Elbow	
0888	1708 W Main ST Last Flow Test: 04/19/2018 949 gpm	Elbow	
0889	3001 Striegel RD Last Flow Test: 05/10/2018 671 gpm		
0890	3101 Striegel RD Last Flow Test: 05/10/2018 671 gpm	Elbow	
0891	1312 E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0892	1310C E Main ST Last Flow Test: 05/08/2018 1210 gpm	Elbow	
0893	1001 E Main ST Last Flow Test: 04/17/2018 1163 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0894	2027 W Main ST Last Flow Test: 04/20/2018 750 gpm		
0895	2605 Kent DR Last Flow Test: 05/08/2018 888 gpm	Elbow	
0896	110 S Rod LANE Last Flow Test: 05/08/2018 581 gpm		
0897	2918 Kent DR Last Flow Test: 05/07/2018 712 gpm		
0898	104 Parrish LN Last Flow Test: 05/08/2018 919 gpm	Elbow	
0899	4 Pinewood DR Last Flow Test: 04/30/2018 581 gpm	Elbow	
0900	2200 New Era RD Last Flow Test: 04/26/2018 750 gpm		
0901	312 W College ST Last Flow Test: 04/10/2018 919 gpm	Elbow	
0902	511 W College ST Last Flow Test: 04/10/2018 750 gpm	Elbow	
0903	609 W College ST Last Flow Test: 04/11/2018 787 gpm		
0904	705 W College ST Last Flow Test: 04/11/2018 888 gpm		
0905	410 Deer Lake DR Last Flow Test: 05/02/2018 822 gpm	Elbow	
0906	460 Deer Lake DR Last Flow Test: 05/02/2018 787 gpm	Elbow	
0907	601 Deer Lake DR Last Flow Test: 05/02/2018 712 gpm	Elbow	
0908	503 Archelle DR Last Flow Test: 05/04/2018 750 gpm	Elbow	
0909	510 Archelle DR Last Flow Test: 05/04/2018 671 gpm	Elbow	
0910	525 Archelle DR Last Flow Test: 05/04/2018 750 gpm	Elbow	
0911	609 E Campus DR Last Flow Test: 04/13/2018 919 gpm	Elbow	
0912	900 W Main ST Last Flow Test: 04/18/2018 1061 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0913	912 W Main ST Last Flow Test: 04/20/2018 1034 gpm		
0914	914 W Main ST Last Flow Test: 04/20/2018 978 gpm		
0915	1317 W Main ST Last Flow Test: 04/20/2018 1007 gpm		
0916	1501 W Main ST Last Flow Test: 04/20/2018 1007 gpm		
0917	1621 W Main ST Last Flow Test: 04/20/2018 978 gpm		
0918	1171C E Main ST Last Flow Test: 05/10/2018 1186 gpm		
0919	1171D E Main ST Last Flow Test: 05/10/2018 1256 gpm		
0920	1171A E Main ST Last Flow Test: 05/10/2018 1278 gpm	Elbow	
0921	1161C E Main ST Last Flow Test: 05/10/2018 1278 gpm	Elbow	
0922	1161D E Main ST Last Flow Test: 05/10/2018 1210 gpm	Elbow	
0923	205 W College ST Last Flow Test: 04/09/2018 919 gpm		
0924	110 S Marion ST Last Flow Test: 04/20/2018 1210 gpm	Elbow	
0925	402 S Marion ST Last Flow Test: 04/19/2018 1138 gpm		
0926	900 E Grand AVE Last Flow Test: 04/12/2018 919 gpm		
0927	1921 S Illinois AVE Last Flow Test: 04/16/2018 1034 gpm	Elbow	
0928	2031 S Illinois AVE Last Flow Test: 04/16/2018 1034 gpm	Elbow	
0929	2071 S Illinois AVE Last Flow Test: 04/16/2018 1061 gpm	Elbow	
0930	2141 S Illinois AVE Last Flow Test: 04/17/2018 1061 gpm	Elbow	
0931	2211 S Illinois AVE Last Flow Test: 04/17/2018 978 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0932	2271 S Illinois AVE Last Flow Test: 04/17/2018 949 gpm	Elbow	
0933	2321 S Illinois AVE Last Flow Test: 04/17/2018 949 gpm	Elbow	
0934	2361 S Illinois AVE Last Flow Test: 04/17/2018 978 gpm	Elbow	
0935	2511 S Illinois AVE Last Flow Test: 04/17/2018 1087 gpm	Elbow	
0936	2571 S Illinois AVE Last Flow Test: 04/17/2018 978 gpm	Elbow	
0937	2651 S Illinois AVE Last Flow Test: 04/17/2018 919 gpm	Elbow	
0938	1400M E Main ST Last Flow Test: 05/09/2018 1256 gpm	Elbow	
0939	903 E Park ST Last Flow Test: 04/10/2018 1034 gpm	Elbow	
0940	2012 S Illinois AVE Last Flow Test: 05/14/2018 856 gpm	Elbow	
0941	1345B E Main ST Last Flow Test: 05/15/2018 1007 gpm		
0942	1633 E Walnut ST Last Flow Test: 05/04/2018 168 gpm	Elbow	
0943	300 S Hunt RD Last Flow Test: 05/04/2018 671 gpm	Elbow	
0944	400 S Hunt RD Last Flow Test: 05/04/2018 531 gpm		
0945	1401 E Sunny Acres RD Last Flow Test: 05/15/2018 1113 gpm		
0946	1451 E Sunny Acres RD Last Flow Test: 05/15/2018 1138 gpm	Elbow	
0947	1204 W Schwartz ST Last Flow Test: 04/12/2018 822 gpm	Elbow	
0948	1225 Allman ST Last Flow Test: 04/26/2018 1087 gpm	Elbow	
0949	1450 E Main ST Last Flow Test: 05/08/2018 1186 gpm	Diffuser and Elbow	
0950	1450 E Main ST Last Flow Test: 05/15/2018 1061 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0951	1450 E Main ST Last Flow Test: 05/08/2018 1186 gpm	Elbow	
0952	1450 E Main ST Last Flow Test: 05/08/2018 1163 gpm		
0953	1450 E Main ST Last Flow Test: 05/08/2018 1186 gpm	Elbow	
0954	1450 E Main ST Last Flow Test: 05/08/2018 1186 gpm	Elbow	
0955	1450 E Main ST Last Flow Test: 05/08/2018 1186 gpm		
0956	1401 E Main ST Last Flow Test: 05/15/2018 671 gpm	Elbow	
0957	S Wall ST & E Park Last Flow Test: 04/09/2018 1233 gpm	Elbow	
0958	606 E Park ST Last Flow Test: 04/09/2018 1087 gpm		
0959	610 E Park ST Last Flow Test: 04/09/2018 1138 gpm	Elbow	
0960	Morningside DR & E Park Last Flow Test: 04/09/2018 1087 gpm	Elbow	
0961	747 E Park ST Last Flow Test: 04/10/2018 1007 gpm		
0962	900 E Park ST Last Flow Test: 04/10/2018 1087 gpm	Elbow	
0963	905 E Park ST Last Flow Test: 04/10/2018 1007 gpm		
0964	1001 E Park ST Last Flow Test: 04/10/2018 949 gpm		
0965	1415 E Main ST Last Flow Test: 05/15/2018 1061 gpm		
0966	S Frances LN & W Sunset Last Flow Test: 05/04/2018 822 gpm	Elbow	
0967	W Sunset DR Last Flow Test: 05/04/2018 787 gpm	Elbow	
0968	Mocking Bird LN Last Flow Test: 05/02/2018 750 gpm	Elbow	
0969	Sassasfras TRL Last Flow Test: 05/02/2018 750 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0970	Foxberry CIR Last Flow Test: 05/02/2018 671 gpm	Elbow	
0971	500 Almond ST Last Flow Test: 04/19/2018 1061 gpm	Elbow	
0972	509 N Almond ST Last Flow Test: 04/19/2018 1061 gpm	Elbow	
0973	609 N Almond ST Last Flow Test: 04/23/2018 1007 gpm		
0974	1100 N Illinois AVE Last Flow Test: 04/26/2018 1113 gpm		
0975	1201 E Main ST Last Flow Test: 05/10/2018 1278 gpm	Elbow	
0976	18 Pine Lake DR Last Flow Test: 05/10/2018 712 gpm	Elbow	
0977	24 Pine Lake DR Last Flow Test: 05/10/2018 787 gpm	Elbow	
0978	11 Pine Lake DR Last Flow Test: 05/10/2018 712 gpm	Elbow	
0979	6 Pine Lake DR Last Flow Test: 05/10/2018 712 gpm	Elbow	
0980	8 Pine Lake DR Last Flow Test: 05/10/2018 712 gpm		
0981	26 Da-Cla-Mar CT Last Flow Test: 05/10/2018 750 gpm	Elbow	
0982	20 Cedar Ridge DR Last Flow Test: 05/10/2018 856 gpm	Elbow	
0983	23 Cedar Ridge DR Last Flow Test: 05/10/2018 856 gpm	Elbow	
0984	24 Cedar Ridge DR Last Flow Test: 05/10/2018 822 gpm	Elbow	
0985	1 Fountain CT Last Flow Test: 05/10/2018 822 gpm	Elbow	
0986	5 Grand Oak DR Last Flow Test: 05/10/2018 856 gpm	Elbow	
0987	7 Grand Oak DR Last Flow Test: 05/10/2018 888 gpm	Elbow	
0988	Mall RD Last Flow Test: 05/10/2018 1256 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
0989	Mall RD Last Flow Test: 05/10/2018 1186 gpm		
0990	1513 Dogwood RD Last Flow Test: 05/02/2018 978 gpm	Elbow	
0991	1145 E Main ST Last Flow Test: 05/10/2018 1233 gpm		
0992	1125 E Main ST Last Flow Test: 05/10/2018 1256 gpm		
0993	E Park ST Last Flow Test: 04/10/2018 787 gpm		
0994	1075 E Park ST Last Flow Test: 04/10/2018 581 gpm		
0995	1080 E Park ST Last Flow Test: 04/10/2018 531 gpm		
0996	1080 E Park ST Last Flow Test: 04/10/2018 531 gpm	Elbow	
0997	1100 E Park ST Last Flow Test: 04/16/2018 336 gpm	Elbow	
0998	E Deer Lake DR Last Flow Test: 05/02/2018 787 gpm	Elbow	
0999	E Deer Lake DR Last Flow Test: 05/02/2018 712 gpm		
1000	605 E Deer Lake DR Last Flow Test: 05/02/2018 712 gpm	Elbow	
1001	632 E Deer Lake DR Last Flow Test: 05/02/2018 628 gpm		
1002	1300 Court LN Last Flow Test: 04/10/2018 581 gpm	Elbow	
1003	Miller CT Last Flow Test: 04/27/2018 1186 gpm		
1004	E Miller CT Last Flow Test: 04/27/2018 1186 gpm		
1005	E Miller CT Last Flow Test: 04/27/2018 1007 gpm		
1006	222 N Emerald LN Last Flow Test: 04/19/2018 949 gpm	Elbow	
1007	2001 W Main ST Last Flow Test: 04/19/2018 888 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1008	Greg LN Last Flow Test: 05/04/2018 787 gpm	Elbow	
1009	Greg LN Last Flow Test: 05/04/2018 787 gpm	Elbow	
1010	Baine DR Last Flow Test: 04/25/2018 787 gpm	Elbow	
1011	Baine DR Last Flow Test: 04/25/2018 787 gpm	Elbow	
1012	Baine DR Last Flow Test: 04/25/2018 750 gpm	Elbow	
1013	2727 W Glenn RD Last Flow Test: 04/27/2018 237 gpm		
1014	2727 W Glenn RD Last Flow Test: 04/27/2018 531 gpm		
1015	200 E College ST Last Flow Test: 04/19/2018 1138 gpm		
1016	620 Cinnabar PT Last Flow Test: 05/02/2018 628 gpm		
1017	621 W Deer Lake DR Last Flow Test: 05/02/2018 712 gpm	Elbow	
1018	710 W Deer Lake DR Last Flow Test: 05/02/2018 712 gpm		
1019	1235 E Walnut ST Last Flow Test: 05/15/2018 949 gpm	Elbow	
1020	117 N Gordon LN Last Flow Test: 05/07/2018 750 gpm	Elbow	
1021	Tower RD Last Flow Test: 05/07/2018 750 gpm	Elbow	
1022	610 Allyn ST Last Flow Test: 04/23/2018 978 gpm		
1023	E Grand AVE & Brehm Last Flow Test: 05/04/2018 750 gpm	Elbow	
1024	E Grand AVE & Brehm Last Flow Test: 05/04/2018 628 gpm		
1025	Pleasant Hill RD & Route 51 Last Flow Test: 04/13/2018 949 gpm	Elbow	
1026	N Diann LN Last Flow Test: 04/27/2018 712 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1027	1103 N Diann LN Last Flow Test: 04/27/2018	0 gpm	
1028	1170 Rendleman RD Last Flow Test: 05/09/2018	1138 gpm	
1029	1170 Rendleman RD Last Flow Test: 05/09/2018	1233 gpm	
1030	1170 Rendleman RD Last Flow Test: 05/09/2018	1186 gpm	
1031	1170 Rendleman RD Last Flow Test: 05/09/2018	1256 gpm	
1032	1170 Rendleman RD Last Flow Test: 05/09/2018	1210 gpm	
1033	1170 Rendleman RD Last Flow Test: 05/10/2018	1321 gpm	Elbow
1034	1170 Rendleman RD Last Flow Test: 05/10/2018	1210 gpm	Elbow
1035	1170 Rendleman RD Last Flow Test: 05/10/2018	1210 gpm	Elbow
1036	1170 Rendleman RD Last Flow Test: 05/10/2018	1186 gpm	Elbow
1037	910 S Wall ST Last Flow Test: 04/18/2018	1186 gpm	
1038	S Wall ST Last Flow Test: 04/12/2018	949 gpm	Elbow
1039	S Wall ST Last Flow Test: 04/18/2018	1186 gpm	
1040	608 S Wall ST Last Flow Test: 04/18/2018	1163 gpm	
1041	E Hester ST Last Flow Test: 04/18/2018	1256 gpm	Elbow
1042	509 S Wall ST Last Flow Test: 04/13/2018	1113 gpm	
1043	S Wall ST & E College Last Flow Test: 04/13/2018	1210 gpm	
1044	600 Cindy ST Last Flow Test: 04/13/2018	1186 gpm	
1045	601 Snider ST Last Flow Test: 04/13/2018	1210 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1046	600 E Eastgate DR Last Flow Test: 04/13/2018 1210 gpm		
1047	600 E Walnut ST Last Flow Test: 04/17/2018 1256 gpm	Elbow	
1048	101 S Wall ST Last Flow Test: 04/17/2018 1300 gpm	Elbow	
1049	601 E Main ST Last Flow Test: 04/17/2018 1300 gpm	Elbow	
1050	600 E Main ST Last Flow Test: 04/17/2018 1300 gpm	Elbow	
1051	Monroe ST Last Flow Test: 04/17/2018 888 gpm		
1052	Dogwood RD Last Flow Test: 05/02/2018 1113 gpm	Elbow	
1053	Dillinger RD Last Flow Test: 04/27/2018 750 gpm		
1054	Pleasant Hill RD Last Flow Test: 04/13/2018 750 gpm	Elbow	
1055	Pleasant Hill RD Last Flow Test: 04/13/2018 1061 gpm	Elbow	
1056	1699 New Era RD Last Flow Test: 04/26/2018 712 gpm		
1057	#3 E Jackson ST Last Flow Test: 04/17/2018 712 gpm	Elbow	
1058	#5 E Jackson ST Last Flow Test: 04/17/2018 671 gpm		
1059	#8 E Jackson ST Last Flow Test: 04/17/2018 750 gpm	Elbow	
1060	#17 E Jackson ST Last Flow Test: 04/17/2018 750 gpm	Elbow	
1061	Dillinger RD Last Flow Test: 04/30/2018 1061 gpm	Elbow	
1062	Dillinger RD Last Flow Test: 04/30/2018 978 gpm	Elbow	
1063	225 Charles RD Last Flow Test: 04/27/2018 1138 gpm	Elbow	
1064	305 Charles RD Last Flow Test: 04/27/2018 1113 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1065	615 Charles RD Last Flow Test: 04/27/2018 1113 gpm		
1066	655 Charles RD Last Flow Test: 04/27/2018 1061 gpm		
1067	1970 Stephens RD Last Flow Test: 04/27/2018 949 gpm		
1068	Stephens RD Last Flow Test: 04/27/2018 856 gpm	Elbow	
1069	825 Charles RD Last Flow Test: 04/27/2018 1138 gpm	Elbow	
1070	Charles RD & N Oakland Last Flow Test: 04/27/2018 1138 gpm	Elbow	
1071	N Oakland AVE Last Flow Test: 04/27/2018 1007 gpm	Elbow	
1072	N Oakland AVE & Lipe Last Flow Test: 04/27/2018 1007 gpm	Elbow	
1073	1200 N Pierce ST Last Flow Test: 05/09/2018 750 gpm	Elbow	
1074	1400 N Pierce ST Last Flow Test: 04/26/2018 1163 gpm	Elbow	
1075	1110 N Allman ST Last Flow Test: 04/26/2018 1210 gpm	Elbow	
1076	1309 North ST Last Flow Test: 04/24/2018 411 gpm	Elbow	
1077	2300 New Era RD Last Flow Test: 04/26/2018 750 gpm		
1078	1300 E Main ST Last Flow Test: 05/09/2018 1034 gpm		
1079	Alveria DR Last Flow Test: 04/30/2018 822 gpm	Elbow	
1080	Alveria DR Last Flow Test: 05/10/2018 750 gpm		
1081	Alveria DR Last Flow Test: 04/30/2018 750 gpm	Elbow	
1082	Chautauqua Villa Last Flow Test: 04/27/2018 856 gpm		
1083	Chautauqua Villa Last Flow Test: 04/27/2018 888 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1084	200 S Oakland AVE Last Flow Test: 04/20/2018 888 gpm	Elbow	
1085	1806 N Illinois AVE Last Flow Test: 04/27/2018 1113 gpm		
1086	1155 Deer Ridge CT Last Flow Test: 05/14/2018 822 gpm		
1087	1425 E Main ST Last Flow Test: 05/15/2018 1061 gpm		
1088	501 N Giant City RD Last Flow Test: 05/14/2018 1113 gpm	Elbow	
1089	501 N Giant City RD Last Flow Test: 05/14/2018 1138 gpm	Elbow	
1090	501 N Giant City RD Last Flow Test: 05/14/2018 1163 gpm	Elbow	
1091	2800 Westridge PL Last Flow Test: 05/09/2018 628 gpm		
1092	2802 Westridge PL Last Flow Test: 05/09/2018 712 gpm	Elbow	
1093	506 Lexington CT Last Flow Test: 05/09/2018 628 gpm	Elbow	
1094	502 Hancock CT Last Flow Test: 05/09/2018 671 gpm	Elbow	
1095	2930 Westridge PL Last Flow Test: 05/09/2018 671 gpm	Elbow	
1096	2950 Westridge PL Last Flow Test: 05/09/2018 712 gpm	Elbow	
1097	2950 Westridge PL Last Flow Test: 05/09/2018 712 gpm	Elbow	
1098	2950 Westridge PL Last Flow Test: 05/09/2018 712 gpm	Elbow	
1099	2950 Westridge PL Last Flow Test: 05/09/2018 671 gpm		
1100	490 Concord CT Last Flow Test: 05/09/2018 671 gpm	Elbow	
1101	482 Concord CT Last Flow Test: 05/09/2018 712 gpm	Elbow	
1102	107 S Springer ST Last Flow Test: 04/18/2018 949 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1103	E Highway 13 Last Flow Test: 05/01/2018 822 gpm		
1104	44 Sweets DR Last Flow Test: 05/01/2018 1163 gpm		
1105	1 Nutrition Plaza DR Last Flow Test: 05/02/2018 978 gpm	Elbow	
1106	2401 McLafferty RD Last Flow Test: 05/11/2018 671 gpm		
1107	2401 McLafferty RD Last Flow Test: 05/11/2018 712 gpm	Elbow	
1108	2401 McLafferty RD Last Flow Test: 05/11/2018 712 gpm	Elbow	
1109	Route 13 W & Wood Last Flow Test: 05/11/2018 581 gpm		
1110	Route 13 W & Wood Last Flow Test: 05/11/2018 531 gpm	Elbow	
1111	Reed Station PKY Last Flow Test: 04/30/2018 1138 gpm	Elbow	
1112	Reed Station PKY Last Flow Test: 04/30/2018 1061 gpm		
1113	Reed Station PKY Last Flow Test: 04/30/2018 1113 gpm		
1114	Reed Station PKY Last Flow Test: 04/30/2018 1087 gpm		
1115	2175 Reed Station PKY Last Flow Test: 04/30/2018 1186 gpm		
1116	2175 Reed Station PKY Last Flow Test: 04/30/2018 1210 gpm	Elbow	
1117	2175 Reed Station PKY Last Flow Test: 04/30/2018 856 gpm		
1118	400 E Main ST Last Flow Test: 04/20/2018 1061 gpm	Elbow	
1119	Route 13 W & Wood Last Flow Test: 05/11/2018 1061 gpm		
1120	802 Woodland Hills Last Flow Test: 04/24/2018 411 gpm		
1121	214 E James and Thelma Walker AVE Last Flow Test: 04/23/2018 1163 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1122	975 Charles RD Last Flow Test: 04/27/2018 978 gpm	Elbow	
1123	975 Charles RD Last Flow Test: 04/27/2018 919 gpm	Elbow	
1124	2131 W Meadow LN Last Flow Test: 04/20/2018 336 gpm		
1125	2121 W Meadow LN Last Flow Test: 04/20/2018 475 gpm	Elbow	
1126	2113 W Meadow LN Last Flow Test: 04/20/2018 411 gpm	Elbow	
1127	920 Kira CT Last Flow Test: 04/27/2018 671 gpm		
1128	875 Norwest LN Last Flow Test: 04/27/2018 628 gpm		
1129	1 Pine Lake DR Last Flow Test: 05/10/2018 671 gpm	Elbow	
1130	201 E Grand AVE Last Flow Test: 04/18/2018 1007 gpm		
1131	601 S Lewis LN Last Flow Test: 05/08/2018 1113 gpm		
1132	601 S Lewis LN Last Flow Test: 05/08/2018 949 gpm		
1133	601 S Lewis LN Last Flow Test: 05/08/2018 1163 gpm	Elbow	
1134	601 S Lewis LN Last Flow Test: 05/08/2018 919 gpm	Elbow	
1135	1150 E Grand AVE Last Flow Test: 05/07/2018 1061 gpm		
1136	1150 E Grand AVE Last Flow Test: 05/07/2018 919 gpm		
1137	1150 E Grand AVE Last Flow Test: 05/07/2018 978 gpm		
1138	1150 E Grand AVE Last Flow Test: 05/07/2018 822 gpm		
1139	1301 E Walnut ST Last Flow Test: 05/11/2018 1113 gpm		
1140	1301 E Walnut ST Last Flow Test: 05/11/2018 1138 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1141	1301 E Walnut ST Last Flow Test: 05/11/2018 1186 gpm		
1142	1301 E Walnut ST Last Flow Test: 05/11/2018 1138 gpm		
1143	1301 E Walnut ST Last Flow Test: 05/14/2018 1210 gpm	Elbow	
1144	1301 E Walnut ST Last Flow Test: 05/11/2018 1138 gpm		
1145	1301 E Walnut ST Last Flow Test: 05/11/2018 1163 gpm		
1146	1301 E Walnut ST Last Flow Test: 05/11/2018 1061 gpm		
1147	1301 E Walnut ST Last Flow Test: 05/11/2018 1138 gpm		
1148	2310A S Illinois AVE Last Flow Test: 04/17/2018 949 gpm	Elbow	
1149	2300C S Illinois AVE Last Flow Test: 04/17/2018 787 gpm	Elbow	
1150	2350 S Illinois AVE Last Flow Test: 04/17/2018 444 gpm	Elbow	
1151	925 W Main ST Last Flow Test: 04/20/2018 978 gpm		
1152	709 S Giant City RD Last Flow Test: 05/08/2018 822 gpm		
1153	410 W Oak ST Last Flow Test: 04/17/2018 1007 gpm		
1154	405 Dixon AVE Last Flow Test: 04/12/2018 712 gpm		
1155	508 E Jackson ST Last Flow Test: 04/17/2018 1256 gpm	Elbow	
1156	516 E Jackson ST Last Flow Test: 04/17/2018 1138 gpm	Elbow	
1157	516 E Jackson ST Last Flow Test: 04/17/2018 1113 gpm		
1158	1075 E Park ST Last Flow Test: 04/10/2018 581 gpm		
1159	1275 Reed Station RD Last Flow Test: 05/02/2018 856 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1160	1275 Reed Station RD Last Flow Test: 05/04/2018	949 gpm	
1161	Reed Station RD Last Flow Test: 05/04/2018	1007 gpm	
1162	239 Reed Station RD Last Flow Test: 05/04/2018	1007 gpm	
1163	1050 Reed Station RD Last Flow Test: 05/04/2018	1007 gpm	
1164	1050 Reed Station RD Last Flow Test: 05/04/2018	978 gpm	
1165	N Reed Station RD Last Flow Test: 05/01/2018	1007 gpm	
1166	Reed Station RD Last Flow Test: 05/01/2018	1061 gpm	
1167	E Walnut ST Last Flow Test: 05/01/2018	1034 gpm	
1168	E Walnut ST Last Flow Test: 05/01/2018	1061 gpm	
1169	E Walnut ST Last Flow Test: 05/01/2018	1007 gpm	
1170	Bigler RD & E Walnut Last Flow Test: 05/04/2018	1186 gpm	
1171	Bigler RD Last Flow Test: 05/04/2018	1186 gpm	
1172	Bigler RD Last Flow Test: 05/15/2018	1113 gpm	
1173	Bigler RD Last Flow Test: 05/04/2018	1210 gpm	
1174	Dillinger RD Last Flow Test: 04/30/2018	1034 gpm	Elbow
1175	819 W Main ST Last Flow Test: 05/14/2018	949 gpm	Elbow
1176	1025 N Wall ST Last Flow Test: 04/27/2018	1087 gpm	Elbow
1177	2300 S Illinois AVE Last Flow Test: 04/17/2018	787 gpm	Elbow
1178	W Elm ST & S University Last Flow Test: 04/11/2018	750 gpm	Elbow

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1179	W Elm ST & S Ash Last Flow Test: 04/11/2018 750 gpm		
1180	1920 S Illinois AVE Last Flow Test: 04/13/2018 750 gpm	Elbow	
1181	E Walnut ST Last Flow Test: 05/11/2018 1138 gpm		
1182	704 E Park ST Last Flow Test: 04/10/2018 1061 gpm	Elbow	
1183	801 S Lewis LN Last Flow Test: 05/07/2018 949 gpm		
1184	801 S Lewis LN Last Flow Test: 05/07/2018 919 gpm	Elbow	
1185	1250 E Grand AVE Last Flow Test: 05/07/2018 888 gpm		
1186	1250 E Grand AVE Last Flow Test: 05/07/2018 856 gpm		
1187	704 E Park ST Last Flow Test: 04/10/2018 1034 gpm	Elbow	
1188	5370 Springer Ridge RD Last Flow Test: 04/16/2018 1163 gpm	Elbow	
1189	1003 Schwartz ST Last Flow Test: 04/10/2018 628 gpm		
1190	2354 New Era RD Last Flow Test: 04/26/2018 712 gpm		
1191	2400 New Era RD Last Flow Test: 04/26/2018 750 gpm		
1192	McLafferty RD Last Flow Test: 05/11/2018 888 gpm		
1193	1627 New Era RD Last Flow Test: 04/26/2018 787 gpm		
1194	2009 Creekwood DR Last Flow Test: 05/01/2018 581 gpm		
1195	2013 Creekwood DR Last Flow Test: 05/01/2018 581 gpm		
1196	30 Pine Lake DR Last Flow Test: 05/10/2018 671 gpm	Elbow	
1197	125 N Gordon LN Last Flow Test: 05/07/2018 750 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1198	955 Villa CT Last Flow Test: 04/30/2018 712 gpm	Elbow	
1199	909 N Carico ST Last Flow Test: 04/24/2018 1034 gpm	Elbow	
1200	307 E Main ST Last Flow Test: 04/20/2018 1034 gpm	Elbow	
1201	1001 Charles RD Last Flow Test: 04/27/2018 888 gpm	Elbow	
1202	1000 N Carico ST Last Flow Test: 04/24/2018 1034 gpm	Elbow	
1203	1009 N Carico ST Last Flow Test: 05/14/2018 1061 gpm	Elbow	
1204	1412 W Main ST Last Flow Test: 04/20/2018 822 gpm		
1205	1412 W Main ST Last Flow Test: 04/20/2018 750 gpm	Elbow	
1206	E Miller CT Last Flow Test: 04/27/2018 1087 gpm		
1207	650 W Baird ST Last Flow Test: 04/24/2018 949 gpm	Elbow	
1208	407 N Smith ST Last Flow Test: 04/23/2018 581 gpm	Elbow	
1209	906 W Burton ST Last Flow Test: 04/23/2018 581 gpm		
1210	Black Diamond DR Last Flow Test: 05/10/2018 822 gpm	Elbow	
1211	Black Diamond DR Last Flow Test: 05/10/2018 712 gpm	Elbow	
1212	1218 Black Diamond DR Last Flow Test: 05/10/2018 822 gpm	Elbow	
1213	Black Diamond DR Last Flow Test: 05/10/2018 712 gpm	Elbow	
1214	Black Diamond DR Last Flow Test: 05/10/2018 671 gpm		
1215	Black Diamond DR Last Flow Test: 05/10/2018 671 gpm		
1216	1435 E Main ST Last Flow Test: 05/15/2018 1061 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1217	Lake RD Last Flow Test: 05/11/2018 787 gpm		
1218	715 N Giant City RD Last Flow Test: 05/15/2018 919 gpm	Elbow	
1219	1271 E Walnut ST Last Flow Test: 05/15/2018 919 gpm	Elbow	
1220	1101 E Grand AVE Last Flow Test: 05/04/2018 949 gpm		
1221	1101 E Grand AVE Last Flow Test: 05/04/2018 949 gpm		
1222	1101 E Grand AVE Last Flow Test: 05/04/2018 856 gpm		
1223	1101 E Grand AVE Last Flow Test: 05/04/2018 978 gpm	Elbow	
1224	1101 E Grand AVE Last Flow Test: 05/04/2018 978 gpm		
1225	1101 E Grand AVE Last Flow Test: 05/04/2018 978 gpm		
1226	1101 E Grand AVE Last Flow Test: 05/04/2018 1087 gpm		
1227	1101 E Grand AVE Last Flow Test: 05/04/2018 1034 gpm	Elbow	
1228	1101 E Grand AVE Last Flow Test: 05/04/2018 1007 gpm	Elbow	
1229	605 Deer Trail Last Flow Test: 05/01/2018 531 gpm	Elbow	
1230	Deer Trail Last Flow Test: 05/02/2018 750 gpm	Elbow	
1231	Deer Trail Last Flow Test: 05/02/2018 671 gpm		
1232	Deer Trail Last Flow Test: 05/02/2018 671 gpm		
1233	Arnold LN Last Flow Test: 04/17/2018 978 gpm	Elbow	
1234	Pleasant Hill RD & S Illinois Last Flow Test: 04/13/2018 978 gpm	Elbow	
1235	Springer Ridge RD & Pleasant Hill Last Flow Test: 04/16/2018 1138 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1236	1208 S Wall ST Last Flow Test: 04/16/2018 1163 gpm	Elbow	
1237	1500 S Wall ST Last Flow Test: 04/16/2018 1163 gpm	Elbow	
1238	1600 S Wall ST Last Flow Test: 04/16/2018 1186 gpm	Elbow	
1239	S Wall ST Last Flow Test: 04/16/2018 1186 gpm	Elbow	
1240	1300 N Marion ST Last Flow Test: 04/30/2018 237 gpm	Elbow	
1241	955 Villa CT Last Flow Test: 04/30/2018 712 gpm		
1242	Saluki BLVD Last Flow Test: 04/12/2018 919 gpm		
1243	Saluki BLVD Last Flow Test: 04/12/2018 1007 gpm	Elbow	
1244	Saluki BLVD Last Flow Test: 04/12/2018 978 gpm	Elbow	
1245	Saluki BLVD Last Flow Test: 04/12/2018 1061 gpm		
1246	Saluki BLVD Last Flow Test: 04/12/2018 978 gpm	Elbow	
1247	Saluki BLVD Last Flow Test: 04/12/2018 1034 gpm	Elbow	
1248	Saluki BLVD Last Flow Test: 04/12/2018 978 gpm	Elbow	
1249	Saluki BLVD Last Flow Test: 04/12/2018 949 gpm	Elbow	
1250	Saluki BLVD Last Flow Test: 04/13/2018 919 gpm	Elbow	
1251	Saluki BLVD Last Flow Test: 04/13/2018 1034 gpm	Elbow	
1252	2541 W Murphysboro RD Last Flow Test: 05/09/2018 712 gpm	Elbow	
1253	N Illinois AVE Last Flow Test: 04/26/2018 856 gpm	Elbow	
1254	McLafferty RD & Pleasant Hill Last Flow Test: 04/13/2018 671 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1255	Foundation DR Last Flow Test: 05/11/2018 628 gpm		
1256	Palm ST Last Flow Test: 04/25/2018 1233 gpm		
1257	Saluki BLVD Last Flow Test: 04/13/2018 949 gpm	Elbow	
1258	2225 Sweets DR Last Flow Test: 05/01/2018 949 gpm		
1259	1445 E Main ST Last Flow Test: 05/15/2018 1007 gpm		
1260	S Illinois AVE Last Flow Test: 05/14/2018 1034 gpm		
1261	803 S Johnson AVE Last Flow Test: 05/14/2018 750 gpm		
1262	2525 Fairview DR Last Flow Test: 05/01/2018 1113 gpm		
1263	2525 Fairview DR Last Flow Test: 05/01/2018 1061 gpm		
1264	Reed Station PKY Last Flow Test: 04/30/2018 1087 gpm	Elbow	
1265	Saluki BLVD Last Flow Test: 04/13/2018 978 gpm	Elbow	
1266	Saluki BLVD Last Flow Test: 04/13/2018 949 gpm	Elbow	
1267	S State ST & E Grand Last Flow Test: 04/18/2018 1163 gpm		
1268	515 S Orchard DR Last Flow Test: 04/12/2018 531 gpm		
1269	3100 W Chautauqua ST Last Flow Test: 05/11/2018 531 gpm		
1270	W Chautauqua ST Last Flow Test: 05/11/2018 531 gpm		
1271	2431 W Main ST Last Flow Test: 05/10/2018 888 gpm	Elbow	
1272	N Cedar CT Last Flow Test: 04/27/2018 628 gpm		
1273	N Cedar CT Last Flow Test: 04/27/2018 531 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1274	N Helen ST Last Flow Test: 04/20/2018 1163 gpm	Elbow	
1275	900 E Park ST Last Flow Test: 04/10/2018 1034 gpm	Elbow	
1276	900 E Park ST Last Flow Test: 04/10/2018 1061 gpm	Elbow	
1277	900 E Park ST Last Flow Test: 04/10/2018 628 gpm		
1278	900 E Park ST Last Flow Test: 04/10/2018 856 gpm	Elbow	
1279	900 E Park ST Last Flow Test: 04/10/2018 671 gpm	Elbow	
1280	900 E Park ST Last Flow Test: 04/10/2018 822 gpm	Elbow	
1281	900 E Park ST Last Flow Test: 04/10/2018 856 gpm	Elbow	
1282	900 E Park ST Last Flow Test: 04/10/2018 787 gpm	Elbow	
1283	1245 E Grand AVE Last Flow Test: 05/07/2018 822 gpm		
1284	Financial Park DR Last Flow Test: 05/11/2018 1138 gpm		
1285	Financial Park DR Last Flow Test: 05/11/2018 1138 gpm		
1286	Financial Park DR Last Flow Test: 05/11/2018 1061 gpm		
1287	Financial Park DR Last Flow Test: 05/11/2018 1186 gpm		
1288	1503 E Stafford AVE Last Flow Test: 05/04/2018 581 gpm		
1289	500 S Marion ST Last Flow Test: 04/19/2018 1186 gpm		
1290	83 View Valley DR Last Flow Test: 04/17/2018 822 gpm		
1291	2400 Reed Station PKY Last Flow Test: 04/30/2018 1233 gpm		
1292	2629 Union Hill RD Last Flow Test: 04/13/2018 531 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1293	3973 Pleasant Hill RD Last Flow Test: 05/15/2018 411 gpm		
1294	2400 Reed Station PKY Last Flow Test: 04/30/2018 1163 gpm	Elbow	
1295	900 E Park ST Last Flow Test: 04/10/2018 712 gpm		
1296	Saluki BLVD Last Flow Test: 04/13/2018 978 gpm	Elbow	
1297	1620 W Main ST Last Flow Test: 04/24/2018 1210 gpm		
1298	1620 W Main ST Last Flow Test: 04/24/2018 1186 gpm		
1299	401 Glenview DR Last Flow Test: 04/24/2018 1163 gpm		
1300	955 Villa CT Last Flow Test: 04/30/2018 671 gpm		
1301	1340 N Cedar CT Last Flow Test: 04/27/2018 750 gpm		
1302	905 E Main ST Last Flow Test: 04/17/2018 1233 gpm		
1303	921 E Main ST Last Flow Test: 04/17/2018 1233 gpm		
1304	1001 E Main ST Last Flow Test: 04/17/2018 1233 gpm		
1305	1010 W Gher ST Last Flow Test: 04/20/2018 1034 gpm	Elbow	
1306	1601 New Era RD Last Flow Test: 04/26/2018 856 gpm	Elbow	
1307	1601 New Era RD Last Flow Test: 04/26/2018 787 gpm	Elbow	
1308	2524 W Murphysboro RD Last Flow Test: 05/10/2018 888 gpm		
1309	1240 E Main ST Last Flow Test: 05/09/2018 1087 gpm	Elbow	
1310	Reed Station PKY Last Flow Test: 04/30/2018 1113 gpm		
1311	1 Nutrition Plaza DR Last Flow Test: 05/02/2018 1061 gpm	Elbow	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1312	1 Nutrition Plaza DR Last Flow Test: 05/02/2018 1061 gpm	Elbow	
1313	1201 S Giant City RD Last Flow Test: 05/02/2018 856 gpm		
1314	1225 S Giant City RD Last Flow Test: 05/02/2018 856 gpm	Elbow	
1315	925 S Giant City RD Last Flow Test: 05/02/2018 978 gpm		
1316	N McRoy DR Last Flow Test: 04/27/2018 978 gpm		
1317	905 E Park ST Last Flow Test: 04/10/2018 919 gpm	Elbow	
1318	1345 Vercliff DR Last Flow Test: 05/01/2018 475 gpm		
1319	1401 Bobbette LN Last Flow Test: 05/01/2018 475 gpm		
1320	1332 Vercliff DR Last Flow Test: 05/01/2018 411 gpm		
1321	1300 Vercliff DR Last Flow Test: 05/01/2018 237 gpm		
1322	1410 Glopen ST Last Flow Test: 05/01/2018 411 gpm		
1323	1510 Glopen ST Last Flow Test: 05/01/2018 475 gpm		
1324	1510 Bobbette LN Last Flow Test: 05/01/2018 411 gpm		
1325	Larsue LN Last Flow Test: 05/01/2018 531 gpm		
1326	1509 S Giant City RD Last Flow Test: 05/01/2018 531 gpm		
1327	1020 Autumn PT Last Flow Test: 04/30/2018 475 gpm	Elbow	
1328	1382 E Main ST Last Flow Test: 05/09/2018 1061 gpm		
1329	1809 W Main ST Last Flow Test: 04/19/2018 411 gpm	Elbow	
1330	401 Glenview DR Last Flow Test: 04/24/2018 1087 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1331	S Tower RD Last Flow Test: 04/30/2018 475 gpm		
1332	1007 E Park ST Last Flow Test: 04/10/2018 712 gpm		
1333	4700 Springer Ridge RD Last Flow Test: 04/16/2018 1300 gpm	Elbow	
1334	2194 Union Hill RD Last Flow Test: 04/13/2018 475 gpm	Elbow	
1335	1101 S Wall ST Last Flow Test: 04/09/2018 1210 gpm	Elbow	
1336	2940 Westridge PL Last Flow Test: 05/09/2018 671 gpm	Elbow	
1337	50 Old Cedar LN Last Flow Test: 04/17/2018 712 gpm	Elbow	
1338	2622 New Era RD Last Flow Test: 05/11/2018 475 gpm		
1339	2534 New Era RD Last Flow Test: 05/11/2018 475 gpm		
1340	900 S Lewis LN Last Flow Test: 04/10/2018 978 gpm	Elbow	
1341	1000 E Cindy ST Last Flow Test: 04/13/2018 1087 gpm		
1342	908 E Cindy ST Last Flow Test: 04/13/2018 1113 gpm		
1343	407 S Cedarview ST Last Flow Test: 04/13/2018 1061 gpm		
1344	401 S Cedarview ST Last Flow Test: 04/13/2018 1113 gpm		
1345	317 S Crestview LN Last Flow Test: 04/13/2018 1113 gpm		
1346	309 S Crestview LN Last Flow Test: 04/13/2018 1113 gpm	Elbow	
1347	308 S Cedarview ST Last Flow Test: 04/13/2018 1034 gpm		
1348	E Miller CT Last Flow Test: 04/27/2018 237 gpm		
1349	S Lynda ST & S Cedarview Last Flow Test: 04/13/2018 1163 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
1350	Heartwood DR Last Flow Test: 05/09/2018 1061 gpm		
1351	Heartwood DR Last Flow Test: 05/09/2018 1007 gpm		
1352	1650 Dogwood RD Last Flow Test: 05/02/2018 1061 gpm	Elbow	
1353	324 Birchlane DR Last Flow Test: 04/13/2018 1087 gpm		
1354	803 E Dorthella ST Last Flow Test: 04/13/2018 1034 gpm	Elbow	
1355	321 S Lynda ST Last Flow Test: 04/13/2018 1163 gpm		
1356	306 S Lynda ST Last Flow Test: 04/13/2018 1113 gpm	Elbow	
1357	1075 E Park ST Last Flow Test: 04/10/2018 671 gpm		
1358	912 N Michaels ST Last Flow Test: 05/11/2018 1034 gpm		
1359	105 Dillinger RD Last Flow Test: 04/30/2018 978 gpm	Elbow	
1360	625 S Lewis LN Last Flow Test: 05/08/2018 712 gpm	Elbow	
1361	801 W Grand AVE Last Flow Test: 05/15/2018 1061 gpm		
A1	16 Logan DR Last Flow Test: 03/01/2013 1163 gpm		
A10	200 Physical Plant DR Last Flow Test: 03/01/2013 1113 gpm		
A11	200 Physical Plant DR Last Flow Test: 03/01/2013 1034 gpm		
A12	265 Neely DR Last Flow Test: 03/01/2013 1113 gpm		
A13	265 Neely DR Last Flow Test: 03/01/2013 1113 gpm		
A14	265 Neely DR Last Flow Test: 03/01/2013 888 gpm		
A15	275 Neely DR Last Flow Test: 03/01/2013 1113 gpm		

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
A16	275 Neely DR Last Flow Test: 03/01/2013	888 gpm	
A17	355 Neely DR Last Flow Test: 03/01/2013	581 gpm	
A18	330 Neely DR Last Flow Test: 03/01/2013	1061 gpm	
A19	370 Neely DR Last Flow Test: 03/01/2013	1061 gpm	
A2	1225 S Washington ST Last Flow Test: 03/01/2013	1138 gpm	
A20	330 Neely DR Last Flow Test: 03/01/2013	856 gpm	
A21	275 Neely DR Last Flow Test: 03/01/2013	822 gpm	
A22	200 Physical Plant DR Last Flow Test: 03/01/2013	0 gpm	
A23	200 Physical Plant DR Last Flow Test: 03/01/2013	291 gpm	
A24	E Park ST Last Flow Test: 03/01/2013	822 gpm	
A25	E Park ST Last Flow Test: 03/01/2013	919 gpm	
A3	1225 S Washington ST Last Flow Test: 03/01/2013	1087 gpm	
A4	1225 S Washington ST Last Flow Test: 03/01/2013	1210 gpm	
A5	Logan DR Last Flow Test: 03/01/2013	888 gpm	
A6	E Tennis DR Last Flow Test: 03/01/2013	1061 gpm	
A7	W Tennis DR Last Flow Test: 03/01/2013	1138 gpm	
A8	1350 Point DR Last Flow Test: 03/01/2013	1034 gpm	
A9	1350 Point DR Last Flow Test: 03/01/2013	949 gpm	
B1	1635 Logan DR Last Flow Test: 03/01/2013	787 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
B10	400 Southern Hills DR Last Flow Test: 03/01/2013	919 gpm	
B11	420 Southern Hills DR Last Flow Test: 03/01/2013	919 gpm	
B12	400 Southern Hills DR Last Flow Test: 03/01/2013	787 gpm	
B13	410 Southern Hills DR Last Flow Test: 03/01/2013	822 gpm	
B2	1615 Logan DR Last Flow Test: 03/01/2013	822 gpm	
B3	1605 Logan DR Last Flow Test: 03/01/2013	888 gpm	
B4	1640 Logan DR Last Flow Test: 03/01/2013	0 gpm	X
B5	1620 Logan DR Last Flow Test: 03/01/2013	0 gpm	X
B6	1600 Logan DR Last Flow Test: 03/01/2013	0 gpm	X
B7	1595 Logan DR Last Flow Test: 03/01/2013	888 gpm	
B8	1585 Logan DR Last Flow Test: 03/01/2013	919 gpm	
B9	1565 Logan DR Last Flow Test: 03/01/2013	919 gpm	
C10	Lincoln DR Last Flow Test: 03/01/2013	919 gpm	
C11	Lincoln DR Last Flow Test: 03/01/2013	712 gpm	
C12	225 Travel Service DR Last Flow Test: 03/01/2013	919 gpm	
C13	1225 Lincoln DR Last Flow Test: 03/01/2013	750 gpm	
C14	1245 Lincoln DR Last Flow Test: 03/01/2013	750 gpm	
C15	1231 Lincoln DR Last Flow Test: 03/01/2013	888 gpm	
C16	1205 Lincoln DR Last Flow Test: 03/01/2013	0 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
C17	1365 Douglas DR Last Flow Test: 03/01/2013	0 gpm	
C3	1400 Arena DR Last Flow Test: 03/01/2013	750 gpm	
C4	1365 Douglas DR Last Flow Test:	gpm	
C5	1365 Douglas DR Last Flow Test: 03/01/2013	888 gpm	
C6	1365 Douglas DR Last Flow Test: 03/01/2013	949 gpm	
C7	1365 Douglas DR Last Flow Test: 03/01/2013	856 gpm	
C8	1365 Douglas DR & Lincoln Last Flow Test: 03/01/2013	787 gpm	
C9	Lincoln DR Last Flow Test: 03/01/2013	919 gpm	
D1	1000 S Normal AVE Last Flow Test: 07/08/2010	0 gpm	
D10	1000 Faner DR Last Flow Test: 05/01/2013	336 gpm	
D11	1000 Faner DR Last Flow Test: 05/01/2013	0 gpm	
D12	1000 Faner DR Last Flow Test: 05/01/2013	0 gpm	
D13	475 Clocktower DR Last Flow Test: 05/01/2013	750 gpm	
D14	475 Clocktower DR Last Flow Test: 05/01/2013	237 gpm	
D2	1075 S Normal AVE Last Flow Test: 07/08/2010	0 gpm	
D3	1075 S Normal AVE Last Flow Test: 07/08/2010	0 gpm	
D4	1100 S Normal AVE Last Flow Test: 05/01/2013	787 gpm	
D5	1265 Lincoln DR Last Flow Test: 05/01/2013	712 gpm	
D6	1100 Lincoln DR Last Flow Test: 05/01/2013	671 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
D7	1259 Lincoln DR Last Flow Test: 05/01/2013	671 gpm	
D8	1000 Faner DR Last Flow Test: 07/08/2010	712 gpm	
D9	1000 Faner DR Last Flow Test: 05/01/2013	0 gpm	
E00	600 Agriculture DR Last Flow Test: 05/01/2013	581 gpm	
E1	555 Clocktower DR Last Flow Test: 05/01/2013	531 gpm	
E10	565 W Grand AVE Last Flow Test: 05/01/2013	1061 gpm	
E11	1125 Lincoln DR Last Flow Test: 05/01/2013	888 gpm	
E12	1135 Lincoln DR Last Flow Test: 05/01/2013	671 gpm	
E13	1135 Lincoln DR Last Flow Test: 05/01/2013	671 gpm	
E14	1135 Lincoln DR Last Flow Test: 05/01/2013	581 gpm	
E16	1135 Lincoln DR Last Flow Test: 05/01/2013	712 gpm	
E17	750 Communications DR Last Flow Test: 05/01/2013	628 gpm	
E18	1205 Lincoln DR Last Flow Test: 05/01/2013	628 gpm	
E19	1205 Lincoln DR Last Flow Test: 05/01/2013	671 gpm	
E2	580 W Grand AVE Last Flow Test: 05/01/2013	531 gpm	
E3	580 W Grand AVE Last Flow Test: 05/01/2013	712 gpm	
E5	1075 Lincoln DR Last Flow Test: 05/01/2013	750 gpm	
E6	1075 Lincoln DR Last Flow Test: 05/01/2013	750 gpm	
E7	1075 Lincoln DR Last Flow Test: 05/01/2013	750 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
E8	565 W Grand AVE Last Flow Test: 05/01/2013	0 gpm	X
E9	555 W Grand AVE Last Flow Test: 05/01/2013	475 gpm	
F1	1205 Lincoln DR Last Flow Test: 07/08/2010	712 gpm	
F17	1205 Lincoln DR Last Flow Test: 07/08/2010	628 gpm	
F2	1205 Lincoln DR Last Flow Test: 07/08/2010	787 gpm	
G1	1150 Douglas DR Last Flow Test: 05/01/2013	949 gpm	
G10	1835 University Press DR Last Flow Test: 05/01/2013	531 gpm	
G11	1915 University Press DR Last Flow Test: 05/01/2013	628 gpm	
G12	1945 University Press DR Last Flow Test: 05/01/2013	475 gpm	
G13	1985 Wildlife DR Last Flow Test: 05/01/2013	671 gpm	
G14	McLafferty RD Last Flow Test: 07/08/2010	671 gpm	
G2	1232 Douglas DR Last Flow Test: 05/01/2013	787 gpm	
G3	1252 Douglas DR Last Flow Test: 05/01/2013	856 gpm	
G4	1300 Point DR Last Flow Test: 05/01/2013	787 gpm	
G5	1250 Point DR Last Flow Test: 05/01/2013	919 gpm	
G6	1215 Douglas DR Last Flow Test: 05/01/2013	856 gpm	
G7	1150 Douglas DR Last Flow Test: 05/01/2013	336 gpm	
G8	1435 Poultry Center RD Last Flow Test: 05/01/2013	692 gpm	
H1	Douglas DR & Saluki Last Flow Test: 07/08/2010	787 gpm	

City of Carbondale Fire Department

Hydrant List (Summary)

All Applicable Records

Hydrant No	Location	Notes	Out of Svc
H10	1950 W Evergreen Terrace DR Last Flow Test: 07/08/2010	581 gpm	
H11	1900 W Evergreen Terrace DR Last Flow Test: 07/08/2010	712 gpm	
H12	1915 W Evergreen Terrace DR Last Flow Test: 07/08/2010	581 gpm	
H13	1965 W Evergreen Terrace DR Last Flow Test: 07/08/2010	531 gpm	
H15	1400 Douglas DR Last Flow Test: 07/08/2010	712 gpm	
H16	Douglas DR Last Flow Test: 07/08/2010	475 gpm	
H17	Douglas DR Last Flow Test: 07/08/2010	581 gpm	
H18	Douglas DR Last Flow Test: 07/08/2010	712 gpm	
H19	Douglas DR Last Flow Test: 07/08/2010	671 gpm	
H2	Douglas DR Last Flow Test: 07/08/2010	888 gpm	
H20	Douglas DR Last Flow Test: 07/08/2010	671 gpm	
H21	1455 Douglas DR Last Flow Test: 07/08/2010	336 gpm	
H3	Douglas DR Last Flow Test: 07/08/2010	750 gpm	
H4	W Evergreen Terrace DR Last Flow Test: 07/08/2010	750 gpm	
H5	W Evergreen Terrace DR Last Flow Test: 07/08/2010	712 gpm	
H6	W Evergreen Terrace DR Last Flow Test: 07/08/2010	787 gpm	
H7	2025 W Evergreen Terrace DR Last Flow Test: 07/08/2010	475 gpm	
H8	2041 W Evergreen Terrace DR Last Flow Test: 07/08/2010	531 gpm	
H9	1961 W Evergreen Terrace DR Last Flow Test: 07/08/2010	411 gpm	

Total Hydrants Listed: 1482